

# Certificate of Compliance

**Certificate:** 214007

**Project:** 1272986

**Date Issued:** January 24, 2002

**Issued to:** Pepperl + Fuchs GmbH  
P.O. Box 310440, Koenigsberger Allee 87  
Mannheim 31, 68307  
Germany  
Attn: Mr. Hogerle

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:**

  
Nancy Graham

**Authorized by:** Ray Fadavi, P. Eng., MBA  
Operations Manager

## PRODUCTS

Class No:2252 01 PROCESS CONTROL EQUIPMENT

- Vibrating Limit Switch Vibracon Type LVL-T1-\*\*\*-\*\*\*\*-CG, rated 19 to 250V ac, 50/60Hz, 350mA or 10 to 55V dc, 350mA. Max ambient 70C.

## MARKINGS

The CSA Mark, the company name, and/or tradename/ or identification/ or file number 214007 , model designation, and any 'Cautions' or other information as specified in the Certification Report.

## *Supplement to Certificate of Compliance*

Certificate: 214007

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

Revision	Date	Description	Listee
		<u>Submittor</u> <u>Endress &amp; Hauser</u>	<u>Listee</u> <u>Pepperl + Fuchs</u>
LR 52694 1272986	Jan. 24/2002	FTL260-3***	LVL-T1-***-****-CG