



HAZARDOUS LOCATION
Class I, Div. 1, 2, Groups A, B, C, D
Class I, Zone 0, IIC, Zone 2, IIC
Class II, Div. 1, 2, Groups E, F, G
Class III

F^{}-Type- Housing:**
IS I, II, III / 1 A,B,C,D,E,F,G



NON HAZARDOUS LOCATION

Intrinsically safe installation
Intrinsically safe (entity). Class I, Div. 1, Group A, B, C, D or Zone 0 IIC Hazardous Location Installation
1. Control room equipment may not use or generate over 250 Vrms.
2. Installation should be in accordance with the National Electrical Code NFPA 70 (NEC) and ANSI / ISA RP12.06.01.

3. Warning: Substitution of components may impair intrinsic safety.
4. Use FM Approvals Entity-Approved Intrinsic safety barrier with $U_{OC} \leq U_{Vmax}$, $I_{OC} \leq I_{Vmax}$, $C_O \geq C_i + C_{cable}$, $L_O \geq L_i + L_{cable}$
5. Barrier must be incapable of delivering more than 1 Watt to a matched load.
- Transmitter entity parameters are as follows:

U/V _{max} (V)	I _i /I _{max} (mA)	P/I _{Pmax} (W)	C _i (nF)	L _i (μH)
30	300	1.0	≤ 13	0

5. Use supply wires suitable for 5 K above surrounding ambient.
6. Intrinsic safety barrier manufacturer's installation drawing must be followed when installing this equipment.
- The configuration of the intrinsic safety barrier(s) must be approved by FM Approvals.
- This version of Prosonic M may be provided with a connection to an external display unit already installed or via a set up kit. This connection is for the use of the FM approved display unit LUC-Z40-Ex1* only.
- Refer to safety instructions of the external display unit LUC-Z40-Ex1*.

Division 2 and Zone 2 installation

Nonincendive Class I, Div. 2, Group A, B, C, D Hazardous Location Installation

1. Installation shall be in accordance with NEC using threaded conduits or other wiring methods in accordance with Article 500 through Article 510. Intrinsic safety barrier not required. Max. supply voltage 30V. For T-code see table.
2. Nonincendive Field Wiring Installation
- The Nonincendive Field Wiring Circuit Concept allows interconnection of nonincendive field wiring apparatus with associated nonincendive field wiring or associated apparatus not specifically examined in combination as a system using any of the wiring methods permitted for unclassified locations, when:

$$V_{max} \geq V_{oc}, C_O \text{ or } C_i + C_{cable}, L_O \text{ or } L_i \geq L_i + L_{cable}$$

Transmitter non-incendive field wiring parameters for this current controlled circuit are as follows:

$$V_{max} = 30 \text{ V}, C \leq 13 \text{ nF}, L = 0 \mu\text{H}, I_{max}^* \text{ see note 3.}$$

3. For this current controlled circuit, the parameter I_{max} is not defined and need not be aligned with parameter I_{sc}

or lo of the barrier or associated nonincendive field wiring apparatus.

4. Warning: Explosion Hazard - Do not disconnect equipment unless power has been switched off or the area is known to be non-hazardous.

Warning: Explosion hazard - substitution of components may impair suitability for Class I, Div. 2.

Class II, III installation

DIP for Class II and III, Div. 1, Group E, F, G Hazardous Location Installation

1. Installation shall be in accordance with NEC using threaded conduits or other wiring methods in accordance with Article 500 through Article 510.
2. Use a dust tight seal at the conduit entry.

Functional Ratings

These ratings do not supersede Hazardous Locations Values
 $V_{nom} = 14...30 \text{ V}, I_{nom} = 4...20 \text{ mA}$

Temperature class with / without Display VII 331	Permissible maximum medium temperature at the sensors	Permissible maximum ambient (T_a) of electronic compartment ('F'-Type enclosure)
T6	+60 °C	LUC-M10- LUC-M20- LUC-M40-
T5	+80 °C	LUC-M10- LUC-M20- LUC-M40-

Area of application:
The compact instruments are suitable for use in areas subject to explosion caused by gases, vapours or mists.

Permissible ambient temperature:
Electronic: 'F'-Type enclosure -40 ... +80 °C resp. -40 ... +176 °F

Type	Type of sensor	Operation temperature [°C resp. °F]
LUC-M10-	1½"-sensor	-40 to +80 resp. -40 to +176
LUC-M20-	2"-sensor	-40 to +80 resp. -40 to +176
LUC-M40-	3"-sensor	-40 to +80 resp. -40 to +176

16-519FM-12 1/8

LUC-M10, LUC-M20, LUC-M40
FM control drawing (F^{**}, IS-HART)

