

Base for PROFIBUS DP, stainless steel version




Function

The base is used in combination with an upper part, the IPT*-FP read/write station.

The device is operated as a slave on the PROFIBUS DP. The device makes available the complete read/write functionality. Up to 32 bytes are transmitted per cycle. Of these, up to 7 double words, each with 32 bits, are available to the user.

The address is set and the terminating resistor for the bus is connected via DIP switches. While the bus termination is switched on, the subsequent subscribers which are connected to the terminals (P, N out) are disconnected from the bus.

Dimensions



Technical Data

Indicators/operating means		
DIP switch		Setting the station address bus connection ON = active OFF = non-active
Electrical specifications		
Rated operating voltage	U _e	20 30 V DC , ripple 10 $\%_{\rm SS}$, PELV
Power consumption	P ₀	max. 5 W with read/write head IPT*-FP
Galvanic isolation		
Operating voltage/interface		functional insulation acc. to DIN EN 50178, rated insulation voltage 50 $\mathrm{V}_{\mathrm{eff}}$
Interface		

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"


Pepperl+Fuchs Group www.pepperl-fuchs.com USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 1111 fa-info@de.pepperl-fuchs.com Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Technical Data	
Physical	RS-485
Protocol	PROFIBUS DP acc. to EN 50170
Transfer rate	9.6; 19.2; 93.75; 187.5; 500; 1500 kBit/s 3; 6; 12 Mbit/s self-synchronizing
Ambient conditions	
Ambient temperature	-25 70 °C (-13 158 °F)
Storage temperature	-40 85 °C (-40 185 °F)
Mechanical specifications	
Degree of protection	IP67 (only in connection with write/read head or cover)
Connection	screw terminals
Interface cable	2 x 0.64 mm ² , double screened, acc. to PROFIBUS standard EN 50170
Supply	up to 3 x 1.5 mm ²
Material	
Housing	stainless steel V4A

Connection



Matching system components



IPT1-FP

LF R/W system, fully assembled as configuration and test station

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

2