





 ϵ







Model Number

ML71-8-200/25/103/115

Diffuse mode sensor with 2 m fixed cable


Features


- Miniature design with front optical face
- Automatic adjustment of sensitivity via TEACH-IN
- Clearly visible function indicators
- Flashing power on LED in case of short-circuit
- · Not sensitive to ambient light
- Protected against mutual interference (no crosstalk)

Product information


Small, robust, effective, and reliable - these are the properties of the ML7 sensor series. Due to their small size, number of versions, and two different lens positions, they are particularly suited for installation in tight spaces. The robust design and high quality of Pepperl+Fuchs mean they can also be used under harsh environmental conditions. The efficient technology, switching frequencies up to 1000 Hz, high resistance to ambient light, and 4-in-1 output make the series suitable for non-contact object detection.

Dimensions







Electrical connection



- O = Light on
- = Dark on

Indicators/operating means





1	Operating display	green
2	Signal display	yellow
3	TEACH-IN button	
4	Emitter	
5	Receiver	

www.pepperl-fuchs.com

Technical data		
General specifications		
Detection range		20 200 mm
Adjustment range		60 200 mm
Reference target		standard white, 100 mm x 100 mm
Light source		LED
Light type		modulated visible red light
Diameter of the light spot		approx. 15 mm at a distance of 200 mm
Angle of divergence		approx. 4.5 °
Ambient light limit		40000 Lux
Functional safety related par	ameters	
MTTF _d		1610 a
Mission Time (T _M)		20 a
Diagnostic Coverage (DC)		0 %
Indicators/operating means		
Operating display		LED green, flashes in case of short-circuit
Function display		LED yellow, lights up with receiver lit
Controls		TEACH-IN key
Electrical specifications		,
Operating voltage	U _B	10 30 V DC , class 2
Ripple	ОВ	max. 10 %
No-load supply current	Io	< 20 mA
	10	< 20 IIIA
Output		light on
Switching type		light on
Signal output		PNP output, short-circuit protected, protected from reverse polarity, open collector
Switching voltage		max. 30 V DC
Switching current		max. 100 mA
Voltage drop	U_d	≤ 1.5 V DC
Switching frequency	f	1000 Hz
Response time		0.5 ms
Ambient conditions		
Ambient temperature		-20 60 °C (-4 140 °F)
Storage temperature		-40 75 °C (-40 167 °F)
Mechanical specifications		
Protection degree		IP67 / IP69K
Connection		2 m fixed cable
Material		
Housing		PC (glass-fiber-reinforced Makrolon)
Optical face		PMMA
Mass		approx. 50 g
Compliance with standards a	and directi	-
Standard conformity		
Product standard		EN 60947-5-2:2007 IEC 60947-5-2:2007
Standards		EN 50178, UL 508
Approvals and certificates		
Protection class		II, rated voltage ≤ 250 V AC with pollution degree 1-2 accoding to IEC 60664-1
UL approval		cULus
CCC annual		Draduata with a maximum aparating valtage of <00 V da na

Accessories

OMH-ML7-01

Mounting bracket

OMH-ML7-02

Mounting bracket


OMH-ML7-03 Fixing plate


Suitable cable sockets can be found in the Internet

Products with a maximum operating voltage of ≤36 V do not bear a CCC marking because they do not require approval.

CCC approval

Curves/Diagrams





TEACH-IN

Connect the sensor to operating voltage, the LED green lights up constantly. The sensor operates at max. sensitivity (delivery status) or with the last teached values.

- Adjust the unit to the target.
- Press the TEACH-IN button as an acknowledge the green LED will switch off shortly for one time.
- Press the TEACH-IN button until both LED's green and yellow are blinking in parallel (2Hz). Release the TEACH-IN button now.
- While the green and yellow LEDs are blinking alternating (2Hz) the unit is in the internal set up procedure.
- TEACH-IN successful: Both LEDs green and yellow are on. The unit is ready to use and in switching mode now.
- TEACH-IN not successful: Both LEDs are flashing alternating (4Hz) for approx. 5 seconds. Afterwards the sensor returns to max. sensitivity setting. Please retry the TEACH-IN procedure beginning by step 1.

www.pepperl-fuchs.com