

NOTES:

1. The Entity Concept allows interconnection of intrinsically safe apparatus with associated apparatus not specifically examined in combination as a system when the approved values of Voc (or Uo), Isc (or Io) and Po for the associated apparatus are less than or equal to Vmax (Ui) and Imax (Ii) for the intrinsically safe apparatus and the approved values of Ca (Co) and La (Lo) for the associated apparatus are greater than Ci + Ccable and Li + Lcable, respectively, for the intrinsically safe apparatus.

The parameters in Table 1 apply when one of the two conditions below is given:

- The total Li of the external circuit (excluding the cable) is < 1% of the Lo value or

- The total Ci of the external circuit (excluding the cable) is < 1% of the Co value.

The parameters in Table 1 are reduced to 50% when both of the two conditions below are given:

- The total Li of the external circuit (excluding the cable) > 1% of the Lo and

- The total Ci of the external circuit (excluding the cable) > 1% of the Co. Note: the reduced capacitance of the external circuit (including cable) shall not be greater than 1uF for C, D (IIB) and 600nF for A, B (IIC).

- 2. Capacitance and inductance of the field wiring from the intrinsically safe equipment to the associated apparatus shall be calculated and must be included in the system calculations as shown in Note 1. Cable capacitance, Ccable, plus intrinsically safe equipment capacitance, Ci must be less than the marked capacitance, Ca (or Co), shown on any associated apparatus used. The same applies for inductance (Lcable, Li and La or Lo, respectively). Where the cable capacitance and inductance per foot are not known, the following values shall be used: Ccable = 60 pF/ft., Lcable = $0.2 \mu \text{H/ft.}$
- 3. Simple Apparatus: An electrical component or combination of components of simple construction with well defined electrical parameters that does not generate more than 1.5 volts, 100 milliamps, and 25 milliwatts, or a passive component that does not dissipate more than 1.3 watts and is compatible with the intrinsic safety of the circuit in which it is used (USA). A switch non-inductive resistive device or thermocouple (Canada).

Dieses Dokument enthält sicherheitsrelevante Angaben. Es darf nicht ohne Absprache mit dem Normenfachmann geändert werden!				
This document contains safety-relevant information. It must not be altered without the authorization of the norm expert!				
CONFIDENTIAL acc. to ISO 16016	Only valid as long as released in EDM	date: 2014-Mar-28		
PEPPERL+FUCHS	Control Drawing for	116-0391		
Worldwide	HiC2081	sheet 1 of 3		

- 4. Wiring methods must be in accordance with the electrical code of the country in use.
- 5. Power, inputs and outputs must be in accordance with Class I, Division 2 wiring methods of National Electrical Code ANSI/NFPA 70, Canadian Electrical Code C22.1 or in accordance with the authority having jurisdiction.
- 6. Intrinsically safe circuits must be wired and separated in accordance with Article 504.20 or other local codes, as applicable. Modules with multiple intrinsically safe field wiring pairs shall be installed as separate intrinsically safe circuits.
- 7. Equipment must be connected to a power supply where the primary and secondary windings of the supply transformer must not be connected to each other.
- 8. The Barrier shall not be connected to any device which uses or generates internally any voltage in excess of 250V Rms or DC unless the device has been determined to adequately isolate the voltage from the barrier.
- 9. The enclosure must be an AEx certified or Ex certified for Canada with a minimum ingress protection of IP54, or in a controlled pollution degree 2 environment. A temperature rating of T4 applies to all nonincendive rated barriers.
- 10. In Class I, Division 2 installations, the subject equipment shall be mounted within a toolsecured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70) or Canadian Electrical Code (C22.1), as applicable.
- 11. In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70) or Canadian Electrical Code (C22.1), as applicable. The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54 unless the apparatus is intended to be afforded an equivalent degree of protection by location
- 12. Connection of the barrier to ground is not required.
- 13. WARNING Substitution of components may impair intrinsic safety and suitability for use in Class I, Div. 2/Zone 2.
 AVERTISSEMENT La substitution de composants peut compromettre la sécurité

intrinsèque et l'adéquation à une utilisation en Classe I, Div. 2/Zone 2.

WARNING - Do not disconnect the equipment or actuate switches when the equipment is energized and an explosive atmosphere is present.

AVERTISSEMENT - Ne pas débrancher l'équipement et ne pas actionner les commutateurs lorsque l'équipement est sous tension et exposé à une atmosphère explosive.

WARNING - Do not use the programming plug when an explosive atmosphere is present. AVERTISSEMENT - Ne pas utiliser de fiche de programmation dans une atmosphère explosive.

For Zone 2 installations, ensure protection of supply terminals against transient voltages exceeding 140% of the rated supply voltage.

Dieses Dokument enthält sicherheitsrelevante Angaben. Es darf nicht ohne Absprache mit dem Normenfachmann geändert werden!					
This document contains safety-relevant information. It must not be altered without the authorization of the norm expert!					
CONFIDENTIAL acc. to ISO 16016	Only valid as long as released in EDM	date: 2014-Mar-28			
PEPPERL+FUCHS		116-0391			
Worldwide	HiC2081	sheet 2 of 3			

	Table 1 - Entity Parameters							
Model Number	Terminals	Voc (Vo) [V]	lsc (lo) [mA]	Po [mW]	Groups	Ca (Co) [uF]	La (Lo) [mH]	Lo/Ro [uH/Ohm]
HiC2081 SL2:1a SL2:1b SL2:5a SL2:5b	9	13.1	30	A,B (IIC)	4.9	207	1158	
				C,E,F,G (IIB)	40	828	4635	
	SL2:5b				D (IIA)	500	1657	9270

Dieses Dokument enthält sicherheitsrelevante Angaben. Es darf nicht ohne Absprache mit dem Normenfachmann geändert werden!				
This document contains safety-relevant information. It must not be altered without the authorization of the norm expert!				
CONFIDENTIAL acc. to ISO 16016	Only valid as long as released in EDM	date: 2014-Mar-28		
EPPPERL+FUCHS		116-0391		
Worldwide	HiC2081	sheet 3 of 3		