Connections

NON-HAZARDOUS LOCATION or HAZARDOUS LOCATION

Class I, Division 1, Groups A, B, C, D

Class II, Division 1, Groups E, F, G

Class III, Division 1 or

Class I, Zone 0 and 1, IIC

Zone 20 and 21, IIIC

NON-HAZARDOUS LOCATION or HAZARDOUS LOCATION Class I, Division 2, Groups A, B, C, D or Class I, Zone 2, IIC

Barrier HiC2441**

(6)

(8)

(9)

Any simple apparatus (2) or approved device with entity concept (1) parameters (Vmax, Imax, Ci, Li) appropriate for connection to associated apparatus with entity concept parameters listed in table below.

Notes

1. The Entity Concept allows interconnection of intrinsically safe apparatus with associated apparatus not specifically examined in combination as a system when the approved values of Voc (or Uo) and Isc (or Io) for the associated apparatus are less than or equal to Vmax (Ui) and Imax(Ii) for the intrinsically safe apparatus and the approved values of Ca(Co) and La(Lo) for the associated apparatus are greater than Ci + Ccable and Li + Lcable, respectively, for the intrinsically safe apparatus,

(3)

(4)

(5)

Where Ccable= 60pF/ft if unknown; Where Lcable= 0.20uH/ft if unknown

- Simple apparatus: an electrical component or combination of components of simple construction with well-defined electrical
 parameters that does not generate more than 1.5 V, 100 mA, 25 mW, or is a passive component that does not disipate
 more than 1.3 W and is compatible with the intrinsic safety of the circuit in which it is used.
- 3. Wiring methods must be in accordance with all applicable installation requirements of the county in use. For US, this is NFPA 70 (NEC) article 504 with additional information in ANSI-ISA –RP12.06.01. For Canada this is CSA 22.1-12 (CEC) section 18 and appendix F.
- 4. Barriers shall not be connected to any device which uses or generates internally any voltage in excess of 250V unless the device has been determined to adequately isolate the voltage from the barrier.
- 5. The device must be installed and operated only in a controlled environment that ensures a pollution degree 2 (or better) according to IEC/EN 60664-1.
 - The device must be installed and operated only in an environment of overvoltage category II (or better) according to IEC/EN 60664-1.
- 6. The barriers are rated `non-incendive` for use in Class I, Division 2 or Zone 2. A temperature rating of T4 applies to all non-incendive rated barriers.
- 7. If the barriers are intended to be mounted in a Division 2 location, they shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70) or Canadian Electrical Code (C22.1), as applicable. The equipment shall be installed in an enclosure with a minimum ingress protection of IP2X.
- 8. If the barriers are intended to be mounted in a Zone 2 location, they shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70) or Canadian Electrical Code (C22.1), as applicable. The equipment shall be installed in an AEx or Ex certified IP54 enclosure unless the apparatus is intended to be afforded an equivalent degree of protection by location.
- 9. The permitted ambient temperature range is -40°C to +70°C

This document contains safety-relevant information. It must not be altered without the authorization of a NE EX					
	date: 2019-Jan-10				
FPEPPERL+FUCHS	UL Control drawing HiC2441**	116-0408			
Global	ПЮ2441	sheet 1 of 2			

Entity Parameters

Model		Uo Io (MA)	lo	Po	Ci	Co (uF)		Lo (mH)			Lo/Ro [uH / Ω]			
Number	Terminal		(mW)	(nF)	A,B IIC	C,E,F,G IIB, IIIC	D IIA	A,B IIC	C,E,F,G IIB, IIIC	D IIA	A,B IIC	C,E,F,G IIB, IIIC	D IIA	
HiC2441**	5a, 1a	12.6	13	41	5.7	1.15	7.4	27	217	868	<1000	886	3547	7094
	5a, 5b	25.2	110	693	5.7	0.101	0.81	2.89	2.9	11.7	23.5	51	204	408
	5a, 1b	7.2	0	0	5.7	13.5	240	1000	Not specified					
		Ui = 2 li = 11			5.7		240	1000	Not specified					

The values of Lo and Co listed in the table above are allowed if one of the following conditions is met:

- the total Li of the external circuit (excluding the cable) is < 1% of the Lo value or
- the total Ci of the external circuit (excluding the cable) is < 1% of the Co value.

The values of Lo and Co listed in the table above shall be reduced to 50% when both of the following conditions are met:

- the total Li of the external circuit (excluding the cable) is \geq 1% of the Lo value and
- the total Ci of the external circuit (excluding the cable) is ≥ 1% of the Co value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than 1uF for IIA, IIB and 600 nF for IIC.

WARNING - Substitution of components may impair intrinsic safety and suitability for use in Class I, Div. 2/Zone 2. AVERTISSEMENT - La substitution de composants peut compromettre la sécurité intrinsèque et l'adéquation à une utilisation en Classe I, Div. 2/Zone 2.

WARNING - Do not disconnect the equipment when the equipment is energized and an explosive atmosphere is present. AVERTISSEMENT - Ne pas débrancher l'équipement lorsque l'équipement est sous tension et exposé à une atmosphère explosive.

This document contains safety-relevant information. It must not be altered without the authorization of a NE EX						
	Only valid as long as released in EDM					
FPEPPERL+FUCHS	UL Control drawing HiC2441**	116-0408				
Global	HIC2441	sheet 2 of 2				