

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion Directive 2014/34/EU**

3 EU - Type Examination Certificate **BAS00ATEX7240X – Issue 12**
Number:

3.1 In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

4 Product: **Type KFD2-SCD2-Ex*.LK Transformer Isolated Driver**

5 Manufacturer: **Pepperl + Fuchs GmbH**

6 Address: **Lilienthalstrasse 200, 68307 Mannheim, Germany**

7 This re-issued certificate extends EC Type Examination Certificate No. BAS00ATEX7240X to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

8.1 The original certificate was issued by The Electrical Equipment Certification Service (UK Notified Body 0600). It, and any supplements previously issued by SGS Baseefa Ltd (UK Notified Body 1180) have been transferred to the supervision of SGS Fimko Oy (EU Notified Body 0598). The original certificate number is retained.

The examination and test results are recorded in confidential Report No.

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018 EN 60079-11:2012

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

See Schedule


SGS Fimko Oy Customer Reference No. **0808**

Project File No. **19/0453**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of their intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Oy
Takomotie 8
FI-00380 Helsinki, Finland
Telephone +358 (0)9 696 361
e-mail sgs.fimko@sgs.com
web site www.sgs.fi

Business ID 0978538-5 Member of the SGS Group (SGA SA)



R S SINCLAIR
Authorised Signatory for SGS Fimko Oy

13

Schedule

14

Certificate Number BAS00ATEX7240X – Issue 12

15 Description of Product

The Type KFD2-SCD2-Ex*.LK Transformer Isolated Driver is a two channel safety device designed to provide a galvanically isolated interface to enable the connection of equipment located in a hazardous area with equipment located in a non-hazardous area by providing galvanic isolation and limiting the voltage and current into the hazardous area to intrinsically safe levels.

The equipment comprises a number of electronics components, including transformers, fuses, resistors and zener diodes, all mounted on a single printed circuit board and housed within a plastic enclosure fitted with terminals for external connections.

The following variants are covered by this certificate:

KFD2-SCD2-Ex1.LK(-Y*)
KFD2-SCD2-Ex2.LK(-Y*)

The safety devices are marked:

⊕ II (1) G [Ex ia Ga] IIC (-40°C ≤ Ta ≤ +60°C/+70°C)

⊕ II (1) D [Ex ia Da] IIIC (-40°C ≤ Ta ≤ +60°C/+70°C)

⊕ I (MI) [Ex ia Ma] I (-40°C ≤ Ta ≤ +60°C/+70°C)

The segregation of the hazardous area circuits meets the requirements for 250V.

Input / Output Parameters

Terminal 7 to 12, 14 & 15 and Power Rail terminals 1, 2 & 4:

KFD2-SCD2-Ex1.LK only: Terminal 7 to 9, 14 & 15 and Power Rail terminals 1, 2 & 4:

$$U_m = 250V$$

The equipment is designed to operate from a d.c. supply of up to 40V.

KFD2-SCD2-Ex2.LK: Terminals 1, 2 & 3 (Ch 1) and 4, 5 & 6 (Ch 2):

KFD2-SCD2-Ex1.LK: Terminals 1, 2 & 3:

$$U_o = 25.2V \quad I_o = 93mA \quad P_o = 585.3mW \quad C_i = 1.05nF \quad L_i = 0$$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the hazardous area load must not exceed the following values:

GROUP	CAPACITANCE (μF)	INDUCTANCE (mH)	OR	L/R RATIO ($\mu H/ohm$)
IIC	0.1059	4.11		60.7
IIB / IIIC	0.818	16.47		242.9
IIA	2.890	32.95		485.9
I	4.790	54.06		797.3

The above parameters apply when one of the two conditions below is given:

- the total L_i of the external circuit (excluding the cable) is < 1% of the L_o value or
- the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total L_i of the external circuit (excluding the cable) $\geq 1\%$ of the L_o value and
- the total C_i of the external circuit (excluding the cable) $\geq 1\%$ of the C_o value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu\text{F}$ for Groups I, IIA & IIB / IIC and 600nF for Group IIC.

16 Report Number

See Certificate History

17 Specific Conditions of Use

1. The safety device must be installed in a controlled environment with a pollution level limited to pollution degree 2 (or better) and be installed within an enclosure providing a degree of protection of at least IP54 according to EN 60529 & EN 60079-0; provision shall be made to ensure that the non-hazardous area connections is limited to overvoltage category I / II as defined in IEC 60664-1.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject	Compliance
1.2.7	LVD type requirements	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility



19 Drawings and Documents




New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
266-0036BS-M	1 of 1	M	2019-Nov-11	Summary
266-0036BS-00M	1 – 21	M	2019-Nov-11	Description
266-0036BS-01M	1 – 5	M	2019-Jun-25	Schematic
266-0036BS-02M	1 & 2	M	2019-Oct-07	Critical Components
266-0036BS-03M	1 – 3	M	2019-Jun-24	Component Overlays
266-0036BS-04M	1 – 15	M	2019-Jul-25	Mechanical Parts
266-0036BS-05M	1 – 7	M	2019-Oct-07	Layouts
266-0036BS-06M	1 – 6	M	2019-Jul-17	Transformer Details
266-0036BS-10M	1 – 3	M	2019-Sep-26	Type Label

20 Certificate History

Certificate No.	Date	Comments
BAS00ATEX7240	11 April 2001	The release of the prime certificate. The associated test and assessment is documented in Test Report 99(C)0589.
BAS00ATEX7240/1	15 January 2002	To permit alternative PCB planar transformers and minor components changes. Test Report No. 01(CI)0721.
BAS00ATEX7240/2	15 March 2002	To permit an alternative PCB layout with minor component changes, alternative PCB planar transformer arrangements and fuse F4 increased to 315mA from 250mA.

Certificate No.	Date	Comments
BAS00ATEX7240/3	30 October 2002	To permit: - minor circuit changes, an alternative PCB layout, minor changes to the planar transformer PCB and minor labelling changes. - removal of certain components to form the single channel KFD2-SCD2-Ex1.LK. - removal of certain components to form the single channel non-SMART KFD2-CD2-Ex1 - removal of certain components to form the dual channel non-SMART KFD2-CD2-Ex2 Project File No. 02/0311.
BAS00ATEX7240/4	4 February 2003	To permit minor changes to the moulded plastic mounting plate that supports the planar transformers. Project File No. 03/0085.
BAS00ATEX7240/5	5 February 2004	To permit minor changes to the PCB. Project File No. 03/1003
BAS00ATEX7240/6	14 December 2004	To permit the removal of fuse type option from the parts list. Project File No. 04/0791.
BAS00ATEX7240/7	25 September 2007	To permit minor changes to the specification of the planar transformer PCBs. Project File No. 07/0190.
BAS00ATEX7240/8	12 November 2009	To permit an alternative version which has short circuit detection disabled, forming types with the –Y1 suffix. To confirm that the equipment covered by this certificate has been reviewed against the requirements of EN 60079-0:2006, and EN 60079-11:2007 in respect of the differences from EN 50014:1997 + Amds 1 & 2 and EN 50020:1994 and that none of these differences affect this equipment. The equipment is also considered suitable for Group I applications and has additionally been assessed against the relevant requirements of EN 61241-11:2006 and the following additional marking may be applied: <div style="text-align: center;">  I (M1) [Ex ia] I  II (1)D [Ex iaD] </div> Report No. GB/BAS/ExTR09.0170/00. Project File No. 09/0567.
BAS00ATEX7240/9	11 October 2011	To permit the use of an alternative PCB design and other minor drawing changes. The Input/Output Parameter table has been updated to include Terminals 3 & 6. Report No. GB/BAS/ExTR11.0226/00. Project File No. 10/0600

Certificate No.	Date	Comments
<p>BAS00ATEX7240 Issue 10</p>	<p>31 October 2014</p>	<p>This issue incorporates previously issued primary and supplementary certificates into one certificate, permits changes to the transformer and confirms that the equipment covered by this certificate has been reviewed against the requirements of EN 60079-0:2012 and EN 60079-11:2012 in respect of the differences from EN 60079-0:2006 and EN 60079-11:2007 and that none of these differences, with the exception of marking, affect this equipment. The equipment is now marked:</p> <p>  II (1)G [Ex ia Ga] IIC  II (1)D [Ex ia Da] IIIC  I (M1) [Ex ia Ma] I </p> <p>Test Report No. GB/BAS/ExTR14.0292/00 Project File No. 14/0400.</p>
<p>BAS00ATEX7240 Issue 11</p>	<p>15 November 2016</p>	<p>To permit the use of alternative components, other minor drawing changes and to confirm that the current design meets the requirements of EN 60079-0: 2012+A11:2013 in respect of the differences from EN 60079-0:2012. Test Report No. GB/BAS/ExTR16.0291/00. Project File No. 16/0060.</p>
<p>BAS00ATEX7240X Issue 12</p>	<p>19 December 2019</p>	<p>To permit the use of alternative PCBs, a small amendment to the Ci and Po figures (together with an amendment to the load parameter table, including adding Group IIIC), a change to the ambient temperature range to $-40^{\circ}\text{C} \leq T_a \leq +60^{\circ}\text{C}/+70^{\circ}\text{C}$, removal of the conformal coating (a specific condition of use now applies), removal of the non-Smart versions, other minor drawing changes and to confirm that the current design meets the requirements of EN IEC 60079-0: 2018 in respect of the differences from EN 60079-0:2012+A11:2013. Test Report No. GB/BAS/ExTR19.0335/00. Project File No. 19/0453.</p>
<p>For drawings applicable to each issue, see original of that issue.</p>		