



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**KFD2-EB2bcd. Power Feed Modules.**

NI / I / 2 / ABCD / T4 Ta = 65°C — 116-0160

I / 2 / AEx nL IIC T4 Ta = 65°C — 116-0160

b = .R4A or blank.

c = .B or .RPI or blank.

d = .SP or blank

*Special conditions for safe use:*

1. The power feed modules shall be installed within an enclosure meeting the requirements of ANSI/ISA-82.02.01 or other applicable ordinary location standards.

### Equipment Ratings:

Nonincendive for use in Class I, Division 2, Group A, B, C, and D T4 Ta = 65°C Hazardous (Classified) Locations.

### FM Approved for:

Pepperl+Fuchs GmbH  
Mannheim, Germany



Member of the FM Global Group

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	2011
Class 3611	2004
Class 3810	1989
Supplement 1	1995

Original Project ID: 3000847

Approval Granted: July 17, 1998

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
010406	April 23, 2001		
060714	November 6, 2006		
RR204312	February 29, 2016		

FM Approvals LLC

J.E. Marquedant  
Manager of Electrical Systems

29 February 2016

Date