

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

LVL-M1(H)- ab-cde-f Vibrating Limit Switch Vibracon (compact version).

IS / I,II,III /1 / ABCDEFG /T5 Ta = 70° C; I / 0 / AEx ia IIC T5 Ta = 70° C; Entity — 16-425FM-12; Type 4X FEL55 Insert:

Vmax = 36 V, Imax = 100 mA, Pi = 1.0 W, Ci = 0, Li = 0.

FEL56 and FEL 58 Insert:

Vmax = 16 V, Imax = 52 mA, Pi = 169 mW, Ci = 0, Li = 0.

 $NI/I/2/ABCD/T5 Ta = 70^{\circ}C; S/II,III/2/FG/T5 Ta = 70^{\circ}C; Type 4X$

- a = Process connection and material: Any combination of three numbers or letters representing industry standard (DIN, ANSI, JIS) threaded bosses and standard flanges for flange, steel, stainless steel and Hastelloy.
- b = Double letter or number representing compact version, compact version with temperature spacer, compact version with gas/pressure tight bushing and surface roughness of medium touching parts.
- c = Enclosure and cable entry: P2 (plastic, NPT 1/2), A2 (Alum, NPT 3/4) or E2 (stainless steel, NPT 1/2), C2 (slim housing NAMUR 316L NPT 1/2"-plug), C6 (slim housing NAMUR 316L PG11-plug) or C4 (slim housing NAMUR 316L M12x1-plug)
- d = Electronic inserts for Div. 1 (f = FI): SI (FEL55), N1 (FEL56) or N2 (FEL58).
- d = Electronic inserts for Div. 2 (f = FN): AC (FEL51), E5 (FEL52), WA (FEL 54), SI (FEL55), N1 (FEL56) or N2 (FEL 58).
- e = Additional Options: Z3 or NA (without additional options)
- f = FM Approval: FI (Div. 1) or FN (Div. 2).

LVL-M2(H)- ab-cde-f Vibrating Limit Switch Vibracon (extended version with lengthening tube). IS / I,II,III / 1 / ABCDEFG / T5 Ta = 70°C; I / 0 / AEx ia IIC T5 Ta = 70°C; Entity — 16-425FM-12; Type 4X FEL55 Insert:

Vmax = 36 V, Imax = 100 mA, Pi = 1.0 W, Ci = 0, Li = 0.

FEL56 and FEL 58 Insert:

Vmax = 16 V, Imax = 52 mA, Pi = 169 mW, Ci = 0, Li = 0.

NI / I / 2 / ABCD / T5 Ta = 70°C; S / II, III / 2 / FG / T5 Ta = 70°C; Type 4X

- a = Process connection and material: Any combination of three numbers or letters representing industry standard (DIN, ANSI, JIS) threaded bosses and standard flanges for flange, steel, stainless steel and Hastelloy.
- b = Double letter or number representing length and material of lengthening tube up to 3000mm, version with temperature spacer, version with gas/pressure tight bushing and surface roughness of medium touching parts.
- c = Enclosure and cable entry: P2 (plastic, NPT 1/2), A2 (Alum, NPT 3/4) or E2 (stainless steel, NPT 1/2), C2 (slim housing NAMUR 316L NPT 1/2"-plug), C6 (slim housing NAMUR 316L PG11-plug) or





- C4 (slim housing NAMUR 316L M12x1-plug).
- d = Electronic inserts for Div. 1 (f = FI): SI (FEL55), N1 (FEL56) or N2 (FEL58).
- d = Electronic inserts for Div. 2 (f = FN): AC (FEL51), E5 (FEL52), WA (FEL 54), SI (FEL55), N1 (FEL56) or N2 (FEL 58).
- e = Additional Options: Z3 or NA (without additional options)
- f = FM Approval: FI (Div. 1) or FN (Div. 2).

LVL-M2C- abc-def-g Vibrating Limit Switch Vibracon (coated version with lengthening tube). IS / I,II,III / 1 / ABCDEFG / T5 Ta = 70°C; I / 0 / AEx ia IIC T5 Ta = 70°C; Entity —16-425FM-12; Type 4X FEL55 Insert:

Vmax = 36 V, Imax = 100 mA, Pi = 1.0 W, Ci = 0, Li = 0.

FEL56 and FEL 58 Insert:

Vmax = 16 V, Imax = 52 mA, Pi = 169 mW, Ci = 0, Li = 0.

NI / I / 2 / ABCD / T5 Ta = 70°C; S / II,III / 2 / FG / T5 Ta = 70°C; Type 4X

- a = Process connection and material: Any combination of three numbers or letters representing industry standard (DIN, ANSI, JIS) threaded bosses and standard flanges for flange, steel, stainless steel and Hastelloy.
- b = Double letter or number representing length and material of lengthening tube up to 3000mm, version with temperature spacer, version with gas/pressure tight bushing (Second Line of Defense).
- c = Pressure tight bushing: B, C, Y or A(without a pressure tight bushing)
- d = Enclosure and cable entry: P2 (plastic, NPT 1/2), A2 (Alum, NPT 3/4) or E2 (stainless steel, NPT 1/2), C2 (slim housing NAMUR 316L NPT 1/2"-plug), C6 (slim housing NAMUR 316L PG11-plug) or C4 (slim housing NAMUR 316L M12x1-plug)
- e = Electronic inserts for Div. 1 (g = FI): SI (FEL55), N1 (FEL56) or N2 (FEL58).
- e = Electronic inserts for Div. 2 (g = FN): AC (FEL51), E5 (FEL52), WA (FEL 54), SI (FEL55), N1 (FEL56) or N2 (FEL 58).
- f = Additional Options: ZD or NA (without additional options)
- g = FM Approval: FI (Div. 1) or FN (Div. 2)

Equipment Ratings:

Intrinsically safe for Class I, II and III, Division 1, Group A, B, C, D, E, F and G, T5 Ta = 70°C; alternatively intrinsically safe for Class I, Zone 0, Group IIC T5 Ta = 70°C in accordance with entity requirements when installed per Installation Drawing 16-425FM-12; nonincendive for Class I, Division 2, Group A, B, C, D, T5 Ta = 70°C; Suitable for Class II, III, Division 2, Group F and G, T5 Ta = 70°C hazardous outdoor (Type 4X) locations.

Approved for:

Pepperl+Fuchs GmbH Königsberger Allee 87 D-68307 Mannheim Germany





This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3610	1999
Class 3611	1999
Class 3810	1989
Class 3810 Supplement #1	1995

Original Project ID: 3013193

FM Approval Granted: June 10, 2002

Subsequent Revision Reports / Date FM Approval Amended

July 14, 2004

Report Number 040604

Date

Report Number

Date


FM Global Technologies LLC

Robert L. Martell, Jr. / Assistant Vice President

FM Approvals

Date

An FM 6/01/8/ Enterprise



Intrinsically safe (entity), Class I, Div.1, Group A,B,C,D Hazardous Location Installations

- 1. Control room equipment may not use or generate over 250 V
- 2. Use FM Approvals Entity-approved intrinsic safety barrier with Voc or Vt \leq Vmax, Isc or It \leq Imax, Ca \geq Ci + C_{cable}, La \geq Li + L_{cable}
- 3. Installation should be in accordance with ANSI/ ISA RP 12.06.01 " Installation of intrinsically safe systems for hazardous (classified) locations" and the National Electrical Code (ANSI/ NFPA 70).
- 4. Warning: Substitution of Components may impair intrinsic safety
- 5. Intrinsic safety barrier manufacturer's installation drawing must be followed, when installing this equipment: The configuration of the intrinsic safety barrier(s) must be FM approved.
- 6. Use supply wires suitable for 5°C above surrounding ambient.

Nonincendive Class I, Div.2, group A,B,C,D and suitable for Class II and III, Div.2 Group F,G Hazardous Location Installation

- Install per National Electrical Code (NEC) using threaded metal conduit. Intrinsic safety barrier not required max. supply voltage 45 VDC
- 2. A dust tight seal must be used at the conduit entry when the transmitter is used in a class II & III location
- 3. Warning: Explosion Hazard- Do not disconnect equipment unless power has been switched off or the area is known to be non hazardous.

 Warning: Substitution of Components may impair suitability for Class I, Div.2