

Member of the FM Global Group

FM Approvals
1151 Boston-Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781 762 9375 www.fmglobal.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

RD0-FB-Ex4. FIELD BARRIER.

NI / I / 2 / ABCD /T4, Ta = 70 °C; - 116-0266 Entity/FISCO

AIS / I,II,III / 1 / ABCDEFG; - 116-0266 Entity/FISCO

[I / 0] AEx [ia] IIC; - 116-0266 Entity/FISCO

Output Entity Parameters:

Uo (Voc) = 15.75 V, lo (Isc) = 247.7 mA, Po = 975.34 mW

Class I, Zone 0, Group IIC Co (Ca) = 0.478 µF

Co (Ca) = 2.88 µF Lo (La)

Class I, Division 1, Groups A & B Class I, Zone 0, Group IIB

Class I & II, Division 1, Groups C & E
Class I, Zone 0, Group IIA

Co (Ca) = 11.6 µF

Co (Ca) = 11.6 μ F Lo (La) = 4.4 mH

Lo (La) = 0.4 mH

Lo (La) = 2.5 mH

Class I, II, III Division 1, Groups D, F, & G

Special Condition for use - Field Barrier shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

aD0-FB-EX4b. FIELD BARRIER.

NI / I / 2 / ABCD /T4, Ta = 70 °C; - 116-0266 Entity/FISCO

AIS / I,II,III / 1 / ABCDEFG; - 116-0266 Entity/FISCO

[1/0] AEx [ia] IIC; - 116-0266 Entity/FISCO

Enclosure Types: NEMA 4X, IP54 (Enclosure option F2)

NEMA 4X (Enclosure option F6)

Output Entity Parameters:

Uo (Voc) = 15.75 V, lo (Isc) = 247.7 mA, Po = 975.34 mW

Class I, Zone 0, Group IIC Co (Ca) = $0.478 \mu F$ Lo (La) = 0.4 mH

Class I, Division 1, Groups A & B

Class I, Zone 0, Group IIB Co (Ca) = $2.88 \,\mu\text{F}$ Lo (La) = $2.5 \,\text{mH}$ Class I & II. Division 1, Groups C & E

Class I, Zone 0, Group IIA Co (Ca) = 11:6 µF Lo (La) = 4.4 mH

Class I, II, III Division 1, Groups D, F, & G

a = Enclosure type - F2 or F6

b = Connection type - CG, CGB, CGS,7/8S, M12B or M12S

Special Condition for use - To maintain NEMA 4X and IP54 enclosure rating, Field Barrier shall be mounted on a solid plate or panel.



Equipment Ratings:

Suitable for Class I, Division 2, Groups A, B, C, and D with intrinsically safe connections for Class I, II, and III, Division 1, Groups A, B, C, D, E, F, and G and Class I, Zone 0, Group IIC, hazardous (classified) indoor (model RD0-FB-Ex4), NEMA 4X and IP54 outdoor (model F2D0-FB-EX4), and NEMA 4X (model F6D0-FB-EX4), locations

Approved for:

Pepperl+Fuchs, Inc. Twinsburg, OH 44087-2245



This certifies that the equipment described has been found to comply with the following FM Approval Standards and other documents:

Class 3600	1998
Class 3610	1999
Class 3611	1999
Class 3810	1989
Including Supplement 1	1995
NEMA 250	1991
ANSI/IEC 60529	2004

Original Project ID: 3015728

FM Approval Granted: January 14, 2004

Date

Report Number

Subsequent Revision Reports / Date FM Approval Amended

Report Number Date

050627 July 6, 2005 051130

AGC. 21 2005

FM Approvals LLC

Robert L. Martell, Jr.

Assistant Vice President

VEC. 21, 2005
Date