CERTIFICATE OF CONFORMITY



1. HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS

2. Certificate No:

FM19US0207X

3. Equipment:

(Type Reference and Name)

KFD2-SR2-Ex*, KFA5-SR2-Ex* and KFA6-SR2-Ex*

Series Switch Amplifier

4. Name of Listing Company:

Pepperl+Fuchs AG

5. Address of Listing Company:

Lilienthalstrasse 200 Mannheim, 68307 Germany

6. The examination and test results are recorded in confidential report number:

3011578 dated 9th August 2001

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM Class 3600:2018, FM Class 3610:2018, FM Class 3611:2018, FM Class 3810:2018, ANSI/ISA 60079-0:2013, ANSI/ISA 60079-11:2014, ANSI/ISA 61010-1:2012, ANSI/UL 12.12.01:2015

- 8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- 9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- 10. Equipment Ratings:

Associated Intrinsically Safe apparatus for connection to Class I, II, III, Division 1, Groups A, B, C, D, E, F and G; Nonincendive for Class I, Division 2, Groups A, B, C and D indoor Hazardous (Classified) locations.

Certificate issued by:

J/E. Marquedant

VP, Manager - Electrical Systems

FM Approvals

6 March 2020

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Mar 16) Page 1 of 4

SCHEDULE



Member of the FM Global Group

US Certificate Of Conformity No: FM19US0207X

11. The marking of the equipment shall include:

For KFD2-SR2-Ex1.W, KFD2-SR2-Ex1.W.LB and KFD2-SR2-Ex2.W:

Class I, Division 2, Groups A, B, C, D, 116-0035 Entity T4 Ta = -40° C to $+70^{\circ}$ C;

IS circuits for: Class I, Division 1, Group A, B, C, D; Class II, Division 1, Group E, F, G; Class III

For other devices:

Class I, Division 2, Groups A, B, C, D, 116-0035 Entity; T4 Ta = -20°C to +60°C;

IS circuits for: Class I, Division 1, Group A, B, C, D; Class II, Division 1, Group E, F, G; Class III

12. Description of Equipment:

General - The switch amplifiers type KF**-SR2-Ex* are used as associated equipment for the transmission of electrical signals from the explosion hazardous area into the non explosion hazardous area. The outputs are designed as relay outputs. The isolated switch amplifiers are manufactured optional with one or two input channels.

Construction - The switchamplifiers type KF**-SR2-Ex* consists of a single compartment, plastic, DIN rail mountable, electronics housing

Power input:

KFD2-SR2-Ex* series:

Power Rail or Terminals (14+, 15-): Rated voltage U = 19...30V DC, Rated current I = 50 mA KFA5-SR2-Ex* series:

Terminals (14, 15): Rated voltage U = 115 V AC±10%, Rated current I = 13 mA KFA6-SR2-Ex* series:

Terminals (14, 15): Rated voltage U = 230 V AC ±10%, Rated current I = 7 mA

IS connections:

Terminals 1,2,3 or 4,5,6: Uo = 12.9 V DC, Io = 19.8 mA

Ouput (relay) Side:

Contact load: 253 V AC at 2 A, 126.5 V AC at 4 A, 40 V DC at 2 A

Isolation: 300 Veff between "Power input" and "Output (relay) side" 375 V peak between "Power input" and "IS-side"

375 V peak between "Output (relay) side" and "IS-side

Ambient Temperature Range:

For KFD2-SR2-Ex1.W, KFD2-SR2-Ex1.W.LB and KFD2-SR2-Ex2.W: -40°C < Ta < 70°C

For other devices: -20°C < Ta < 60°C

Ingress degree of protection: IP20

Connection: Screw terminals

Installation: Installs in a secondary enclosure

Switch Amplifier

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

F 347 (Mar 16) Page 2 of 4

SCHEDULE



Member of the FM Global Group

US Certificate Of Conformity No: FM19US0207X

KFD2-SR2-Ex1.W, KFD2-SR2-Ex1.W.LB and KFD2-SR2-Ex2.W: AIS / I,II,III / 1 / ABCDEFG 116-0035; Entity; NI / I / 2 / ABCD / T4, -40 $^{\circ}$ C < Ta < +70 $^{\circ}$ C Other devices:

AIS / I,II,III / 1 / ABCDEFG 116-0035; Entity; NI / I / 2 / ABCD / T4, -20°C < Ta < +60°C

	// // -	Entity Parameters					
Туре	V _{oc} (V)	I _{sc} (mA)	V _t (V)	I _t (mA)	C _a (µF)	L _a (mH)	
KFD2-SR2-Ex2.2Sa				J. M.	0.0		
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	_	1.33	84.9	
KFD2-SR2-Ex1.W.LBa							
Terminals 1-3, 2-3	12.9	19.8	_	_	1.33	84.9	
KFD2-SR2-Ex1.Wa							
Terminals 1-3, 2-3	12.9	19.8	_	_	1.33	84.9	
KFD2-SR2-Ex2.Wa							
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	_	1.33	84.9	
KFD2-SR2-Ex2.W.SMa	// // >	212	100	35 /	0	0	
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	- 1, //	1.33	84.9	
KFA6-SR2-Ex2.Wa							
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	- 6	<u> </u>	1.33	84.9	
KFA6-SR2-Ex2.W.IRa							
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	_	1.33	84.9	
KFA6-SR2-Ex1.W.LBa							
Terminals 1-3, 2-3	12.9	19.8	_	_	1.33	84.9	
KFA6-SR2-Ex1.Wa							
Terminals 1-3, 2-3	12.9	19.8	_	_	1.33	84.9	
KFA5-SR2-Ex1.W.LBa	/ /		D-1170				
Terminals 1-3, 2-3	12.9	19.8	1 1	7 1 /	1.33	84.9	
KFA5-SR2-Ex1.Wa					P.		
Terminals 1-3, 2-3	12.9	19.8	- 4	- W	1.33	84.9	
KFA5-SR2-Ex2.Wa	H. H. H. H.	0	11 0		- A I		
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	_	1.33	84.9	
KFA5-SR2-Ex2.W.IRa							
Terminals 1-3, 2-3, 4-6, 5-6	12.9	19.8	_	_	1.33	84.9	

a = Special function, not affecting safey.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com <a href="mai

F 347 (Mar 16) Page 3 of 4

SCHEDULE



US Certificate Of Conformity No: FM19US0207X

13. Specific Conditions of Use:

The apparatus shall be installed in compliance with the enclosure, mounting, spacing and segregation requirements of the ultimate application.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
9th August 2001	Original Issue.
6 th March 2020	Supplement 3: Report Reference: – PR455025 dated 6 th March 2020. Description of the Change: Converted to new format certificate. Standards were updated as follows: FM Class 3600 updated to 2018, FM Class 3610 updated to 2018, FM Class 3611 updated to 2018, FM Class 3810 updated to 2018, ANSI/ISA 60079-0 updated to 2013, ANSI/ISA 60079-11 updated to 2014, ANSI/ISA 61010-1 updated to 2012, ANSI/UL 12.12.01 updated to 2015
	KFD2-SR2-Ex1.W, KFD2-SR2-Ex1.W.LB and KFD2-SR2-Ex2.W ambient temperature range of -20°C to 60°C was changed to -40°C to 70°C.
	An alternative (not replacement) layout for KFD-SR2-Ex*.W* devices has been added.
	There has been some modifications to the circuitry including a new transformer.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

F 347 (Mar 16) Page 4 of 4