

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# **CERTIFICATE OF COMPLIANCE**

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

KFD0-SD2-Ex1.1045. Solenoid Driver.
KFD0-SD2-Ex2.1045. Solenoid Driver.
KFD0-SD2-Ex1.1245. Solenoid Driver.
KFD0-SD2-Ex2.1245. Solenoid Driver.
KFD0-SD2-Ex1.1065. Solenoid Driver.
KFD0-SD2-Ex2.1065. Solenoid Driver.
KFD0-SD2-Ex1.10100. Solenoid Driver.
AIS/I,II,III/1/ABCDEFG — 266-031FM-12; Entity
I/0/[AEx ia] IIC — 266-031FM-12; Entity
NI/I/2/ABCD/T4, Ta = 60°C
I/2/AEx nA II T4, Ta = 60°C

Entity Parameters:

Voc, Uo (V)	lsc, lo (mA)	Po (mW)	Group	Ca,Co (μF)	La, Lo (mH)	Lo/Ro (μΗ/Ω)
Type KFD0-SD2-Ex*.1045 – Terminals: Channel 1: 1,2,3 Channel 2: 4,5,6						
			A, B, IIC	0.107	4.11	60
25.2	93	586	C, E, F, G, IIB	0.82	16.44	242
			D, IIA	2.90	32.88	485
Type KFD0-	Type KFD0-SD2-Ex*.1245 – Terminals: Channel 1: 1,2,3 Channel 2: 4,5,6					
			A, B, IIC	0.107	2.93	51
25.2	110	693	C, E, F, G, IIB	0.82	11.75	205
			D, IIA	2.90	23.50	410
Type KFD0-SD2-Ex*.1065 – Terminals: Channel 1: 1,2,3 Channel 2: 4,5,6						
. , , , , , , , , , , , , , , , , , , ,			A, B, IIC	0.353	0.73	37
17.22	220	947	C, E, F, G, IIB	2.06	2.93	150
			D, IIA	8.50	5.87	300
Type KFD0-SD2-Ex1.10100 – Terminals: 1,2,3						
17	271	1152	A, B, IIC	0.375	0.48	30
			C, E, F, G, IIB	2.20	1.93	123



Voc, Uo (V)	lsc, lo (mA)	Po (mW)	Group	Ca,Co (μF)	La, Lo (mH)	Lo/Ro (μΗ/Ω)
			D, IIA	9.00	3.87	246

### Special Conditions of Use:

- 1) In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70).
- 2) In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70). The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54 unless the apparatus is intended to be afforded an equivalent degree of protection by location
- 3) In Class I, Zone 2 installations, the installer shall ensure protection of supply terminals against transient voltages exceeding the rated supply voltage by greater than 40%.

#### KFD0-SD2-Ex1.1180. Solenoid Driver.

AIS/I,II,III/1/CDEFG – 266-031FM-12; Entity I/0/[AEx ia] IIB –266-031FM-12; Entity NI/I/2/ABCD/T4, Ta = 60°C I/2/AEx nA II T4, Ta = 60°C

**Entity Parameters:** 

Voc, Uo (V)	lsc, lo (mA)	Po (mW)	Group	Ca,Co (μF)	La, Lo (mH)	Lo/Ro (μΗ/Ω)
Type KFD0	)-SD2-Ex1.1	180 – Term	inals: 1,2,3			
			A, B, IIC	NA	NA	NA
25.2	184	1159	C, E, F, G, IIB	0.82	4.20	122
			D, IIA	2.90	8.40	245

#### Special Conditions of Use:

- 1) In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70).
- 2) In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70). The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54 unless the apparatus is intended to be afforded an equivalent degree of protection by location.
- 3) In Class I, Zone 2 installations, the installer shall ensure protection of supply terminals against transient voltages exceeding the rated supply voltage by greater than 40%.

## Equipment Ratings:

Model KFD0-SD2-Ex\*.1045, KFD0-SD2-Ex\*.1065 and KFD0-SD2-



Ex1.10100 Solenoid Drivers: Intrinsically safe (entity) connections to Class I, II and III, Division 1, applicable Groups A, B, C, D, E, F and G; intrinsically safe (entity) connections to Class I, [AEx ia] IIC per control drawing 266-031FM-12; nonincendive for Class I, Division 2, Groups A, B, C and D, T4 at Tambient = -20°C to 60°C; non-sparking, AEx nA for Class I, Zone 2, T4 at Tambient = -20°C to +60°C, hazardous (classified) indoor locations.

Model KFD0-SD2-Ex1.1180 Solenoid Driver: Intrinsically safe (entity) connections to Class I, II and III, Division 1, applicable Groups C, D, E, F and G; intrinsically safe (entity) connections to Class I, [AEx ia] IIB per control drawing 266-031FM-12; nonincendive for Class I, Division 2, Groups A, B, C and D, T4 at Tambient = -20°C to 60°C; non-sparking, AEx nA for Class I, Zone 2, T4 at Tambient = -20°C to +60°C, hazardous (classified) indoor locations.

FM Approved for:

Pepperl+Fuchs GmbH Mannheim, Germany



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2007
Class 3611	2004
ANSI/ISA 12.12.02	2003
Class 3810	2005

Original Project ID: 3028278

Approval Granted: FEb 6 2005

Subsequent Revision Reports / Date Approval Amended

Report Number Date Report Number Date

FM Approvals LLC

Assistant Vice President

726 6, 2008 Date