



# CERTIFICATE

No. Z10 11 05 20068 032

**Holder of Certificate:** Pepperl+Fuchs GmbH

Lilienthalstraße 200  
68307 Mannheim  
GERMANY

**Factory(ies):** 62019, 63390

**Certification Mark:**



**Product:** Electro-Sensitive Protective Equipment  
ESPE Type 4

**Model(s):** Safety control unit: SLVA-8K, SC4-8, SLVA-4Kplus

**Parameters:**

Power supply:	24V AC/DC, 115V AC, 230V AC
Nominal current (SLVA-8K/SC4-8):	500mA, 110mA, 50mA
Nominal current (SLVA-8K/SC4-8):	200mA, 100mA, 50mA
I max. of the OSSD: (s. instruction manual)	2A
Degree of protection:	IP20
Operating temperature:	0°C to +50°C

Condition: Use only with certified Safety Light Curtain of series SLA and certified Safety Light Grid of series SLP.

**Tested according to:** EN ISO 13849-1:2008  
(Cat. 4, PL e)  
EN 61496-1:2008  
IEC 61496-2:2006

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** VB51547

( Alfred Beer )

**Date,** 2011-06-01



Page 1 of 1