



America

# CERTIFICATE

No. U10 020068 0095 Rev. 00

**Holder of Certificate:** **Pepperl+Fuchs SE**

Lilienthalstraße 200  
68307 Mannheim  
GERMANY

**Certification Mark:**



**Product:**

**Control units**

**(Safety Control Unit Module Adapter)**

**Tested according to:**

UL 508:2018/R:2021-07  
CSA C22.2 No. 14:2018

This product was voluntarily tested to the relevant safety requirements referenced on this certificate. It can be marked with the certification mark above. The mark must not be altered in any way. The certificate holder shall not transfer this certificate to third parties. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". For Canadian standards TÜV SÜD America Inc. is accredited by the Standards Council of Canada to ISO/IEC 17065.

**Test report no.:**

713259648

**Date,**

2022-06-02

( Susanne Dormann )



America

# CERTIFICATE

No. U10 020068 0095 Rev. 00

**Model(s):** IF-SB4-01 (PN: 213003)

**Brand Name(s):** Pepperl+Fuchs

## Parameters:

Input voltage:	ON: 24 VDC (+20% / -30%) OFF: < 1 VDC
Input current:	15 mA
Output voltage:	24 VDC
Output current:	7.5 mA

## Conditions of Acceptability

When installed in the end use equipment, the following are among the considerations to be made:

- An approved "NEC Class 2 Power Supply" must be used with this equipment.
- If the device is to be installed in French spoken areas, a French "Operation Instruction" shall be delivered.
- Installation and use shall be according to operation instructions