

CERTIFICATE OF CONFORMITY

- HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
- Certificate No:** FM18CA0098X
- Equipment:** KFD0-CS-Ex*.52 Series
(Type Reference and Name) Loop-Powered Current Repeaters
- Name of Listing Company:** Pepperl+Fuchs GmbH
- Address of Listing Company:** Lilienthalstrasse 200
D-68307 Mannheim
Germany
- The examination and test results are recorded in confidential report number:

3033276 dated 4th June 2009
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CAN/CSA-C22.2 No. 60079-0:2011, CAN/CSA-C22.2 No. 60079-11:2014,
CAN/CSA-C22.2 No.60079-15:2002 (Re-affirmed 2006), CAN/CSA-C22.2 No. 61010-1:2004, CAN/CSA-C22.2 No.213:1987 (Re-affirmed 2004)
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:



J.E. Marquedant
Manager Electrical Svstems

24 August 2018

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0098X

10. Equipment Ratings:

Associated intrinsically safe (entity) equipment with connections for Class I, II, III, Division 1, Groups A, B, C, D, E, F, G; Associated intrinsically safe (entity) equipment with [Ex ia] connections for Class I, Zone 0, Group IIC per control drawing 116-0129; Class I, Division 2, Groups A, B, C, D, temperature class T4, Ex nA for Class I, Zone 2, temperature class T4 hazardous locations. The equipment is Approved for use over an ambient temperature range of -20°C to 60°C.

11. The marking of the equipment shall include:

CL I, DIV 2, GP A-D, IS circuits for CL I, II, III, DIV 1, GP A-G; CL I, ZN 2 Ex nA II, IS circuits for CL 1, ZN 0 [Ex ia] IIC, install per 116-0129. Temperature Class T4, Tamb = -20°C to +60°C

12. Description of Equipment:

General – The single or dual-channel galvanically-isolated current repeaters are used for intrinsic safety applications. They are loop-powered and repeat a 4 – 20 mA signal from a current source inside a hazardous location the non-hazardous location. The isolators do not provide power to transmitters within a hazardous location.

Construction - The repeaters utilize a plastic enclosure which is configured for mounting to a 35 mm DIN rail. Connection to field wiring is by way of externally-mounted screw terminals.

Ratings - The repeaters operate from a 4 to 24 V DC source (loop powered) over an input current range of 4 – 20 mA. They are rated for use over an ambient temperature range of -20°C to +60°C.

Model numbers and entity parameters are as follows:

KFD0-CS-Ex1.52 Current Repeater

KFD0-CS-Ex2.52 Current Repeater

Type KFD0-CS-Ex1.52 – Terminals: 1,2 Type KFD0-CS-Ex2.52 – Terminals: 1,2;4,5						
V_{oc}, U_o (V)	I_{sc}, I_o (mA)	P_o (mW)	Group	C_a, C_o (μ F)	L_a, L_o (mH)	L_o / R_o (μ H/ Ω)
25.2	0	0	A, B, IIC	0.107	1000	947
			C, E, F, G, IIB	0.82	1000	947
			D, IIA	2.90	1000	947

13. Specific Conditions of Use:

- 1) In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the Canadian Electrical Code (C22.1).

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0098X

- 2) In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the Canadian Electrical Code (C22.1). The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54 unless the apparatus is intended to be afforded an equivalent degree of protection by location.
- 3) In Class I, Zone 2 installations, the installer shall ensure protection of supply terminals against transient voltages exceeding the rated supply voltage by greater than 40%.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
4 th June 2009	Original issue as certificate 3033276C
24 th August 2018	<u>Supplement: 1</u> Report reference: RR214565 dated 24 th August 2018 Description of Change: Update CSA C22.2 Nos. 60079-0 & 60079-11 to 2011 & 2014 editions, respectively. Remove reference to CSA C22.2 No 157. Approve as associated equipment for connection to Division 1 based upon CSA C22.2 Nos. 60079-0 & 60079-11. Minor changes to construction and documentation. Adopt new format certificate. Relocate critical documentation from file 1B4A7.AX to file 3033276.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE