



FM Approvals
 1151 Boston Providence Turnpike
 P.O. Box 9102 Norwood, MA 02062 USA
 T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

HiC2851. Isolated Safety Switch Amplifier.

AIS/I,II,III/1/ABCDEFG – 16-534FM-12; Entity

I/O/[AEx ia] IIC – 16-534FM-12; Entity

NI/II/2/ABCD/T4, Ta = 60°C

I/2/AEx nA II T4, Ta = 60°C

Entity Parameters:

Voc, Uo (V)	Isc, Io (mA)	Po (mW)	Group	Ca,Co (µF)	La, Lo (mH)	Lo/Ro (µH/Ω)
Terminals: SL2:A5, B5						
10.5	17.1	45	A, B, IIC	2.41	121.5	792
			C, E, F, G, IIB	16.8	486.3	3167
			D, IIA	75	972.7	6334

Specific Conditions of Use:

- 1) In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70).
- 2) In Class I, Zone 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I, Zone 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70). The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54 unless the apparatus is intended to be afforded an equivalent degree of protection by location
- 3) In Class I, Zone 2 installations, the installer shall ensure protection of supply terminals against transient voltages exceeding the rated supply voltage by greater than 40%.



Member of the FM Global Group

Equipment Ratings:

Nonincendive for Class I, Division 2, Group A, B, C, D, T4; non-sparking, AEx nA II T4 for Class I, Zone 2, Group II; associated intrinsically safe apparatus with connections for Class I, II, III, Division 1, applicable Groups A, B, C, D, E, F, G; associated intrinsically safe apparatus [AEx ia] IIC with connections for Class I, Zone 0, Group IIC hazardous (classified) locations. The subject equipment is Approved for an ambient temperature range of -20 to +60°C.

FM Approved for:

Pepperl+Fuchs GmbH
Mannheim, Germany



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3610	2007
Class 3611	2004
Class 3810	2005
ANSI/ISA 12.12.02	2009


Original Project ID: 3033219

Approval Granted: *October 19, 2009*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



J. E. Marquedant
Group Manager, Electrical

19 October 2009

Date