

FM Approvals 1151 Boston Providence Turnpike P.O. Box 9102 Norwood, MA 02062 USA

Member of the FM Global Group

T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

KFD2-RCI-Ex1. Isolator

NI/I/2/ABCD/T4, Ta = 60°C

AIS/I,II,III/1/ABCDEFG - 116-0335; Entity

Entity Parameters:

Voc, Uo (V)	lsc, lo (mA)	Po (mW)	Group	Ca,Co (µF)	La, Lo (mH)	Lo/Ro (μΗ/Ω)
Terminals	: 1(+), 3(-)					
25.4	93.6	595	A, B, IIC	0.104	4.05	60
			C, E, F, G, IIB	0.81	16.2	240
			D, IIA	2.82	32.4	480

Special Condition of Use:

Equipment Ratings:

Associated Intrinsically Safe (Entity) with connections for Class I, II and III, Division 1, Groups A, B, C, D, E, F and G; per control drawing 116-0335; Nonincendive for Class I, Division 2, Groups A, B, C and D, Temperature Class T4 Ta = -20°C to 60°C; Hazardous (Classified) Locations.

FM Approved for:

Pepperl+Fuchs Inc. Twinsburg, OH 44087

¹⁾ In Class I, Division 2 installations, the subject equipment shall be mounted within a tool-secured enclosure which is capable of accepting one or more of the Class I. Division 2 wiring methods specified in the National Electrical Code (ANSI/NFPA 70)



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600 1998 Class 3610 2010 Class 3611 2004 Class 3810 2005

Original Project ID: 3037174

Approval Granted: May 28, 2010

Subsequent Revision Reports / Date Approval Amended

Report Number Date

Report Number

Date

FM Approvals LLC

J/E. Marquedant

Group Manager, Electrical

28 May 2010