



Certificate of Compliance

Certificate: 80078445

Master Contract: 169790

Project: 80078445

Date Issued: 2021-06-29

Issued To: Pepperl+Fuchs SE
Lilienthalstrasse 200
Mannheim, Baden-Wurttemberg, 68307
Germany

Attention: Wolfram Warnecke

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: Neda Shahi
Neda Shahi



PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Frequency to Voltage/Current Converter, Model KFU8-FSSP-1.D, permanently connected, rated 115/230V, 47-63Hz, 5VA; 24Vdc, 5W.

Frequency to Voltage/Current Converter, Model KFU8-FSSP-1.D-Y*, permanently connected, rated 115/230V, 47-63Hz, 5VA; 24Vdc, 5W.

Rotational Speed Monitor, Model KFU8-DW-1.D, permanently connected, rated 115/230V, 47-63Hz, 5VA; 24Vdc, 5W.



Certificate: 80078445
Project: 80078445

Master Contract: 169790
Date Issued: 2021-06-29

Rotational Speed Monitor, Model KFU8-DW-1.D-Y*, permanently connected, rated 115/230V, 47-63Hz, 5VA; 24Vdc, 5W.

Max. Ambient: 40°C.

Note:

1. The above model is rated Pollution Degree 2, and Installation Category II.
2. Certified as components for use in other equipment where the suitability of the combination is to be determined by CSA Group.
3. A suitable fire enclosure is to be provided in the end use.
4. The Determination of Accessible Parts (Cl. 6.2) is to be conducted in the end-use.
5. The subject models have been evaluated for Basic Insulation Only.

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements
- UL Std. No. 61010-1 (2nd Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 80078445

Master Contract: 169790

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80078445	2021-06-29	Previously Certified under Master Contract 159754, Report 2137693, re-issued as Edition 1 under the new Master Contract. Update to report to remove the component special pickup for the PTC thermistors.