SIL Manufacturer's Declaration

Functional safety of inductive proximity sensors acc. to IEC 61508:2000; PF20CERT1624F

1 Safety Evaluation

Pepperl+Fuchs SE, Lilienthalstrasse 200, 68307 Mannheim

declares as manufacturer that for the inductive proximity sensors, types mentioned below, the calculated PFD_{avg} values for low demand mode of operation are within the allowed range for SIL 2 according to IEC 61508-1:2000 table 2 and do fulfil the requirement to not claim more than 25% of this range, i.e. to be better than or equal to 2.5 · 10⁻³.

For high demand mode of operation, the PFH is within the allowed range for SIL 2 according to IEC 61508-1:2000 table 3. It fulfils the requirement to not claim more than 25% of this range, i.e. to be better than or equal to $2.5 \cdot 10^{-7}$ 1/h.

The sensors are considered to be Type A components. Therefore, the SFF has to be 60 % to 90 % according to EN/IEC 61508-2 table 2 for SIL 2 (sub-) systems with a hardware fault tolerance of 0.

2 Products

Inductive proximity sensors with NAMUR interface in accordance with IEC 60947-5-6:1999 or EN 60947-5-6:2000, see product list.

The nominal sensing distance s_n and therefore the assured release distances s_{ar} depend on the dimensions and the material of the target. The distance is the air gap between the target surface and the sensing face while the reference target is in parallel with the sensing face, is centered to the reference axis and is moving along the reference axis.

Product List, Nominal Sensing Distance (s_n) , Assured Release Distance (s_{ar}) and Targets

Part No.	Product Name	Function ¹⁾	Sn	s _{ar} Reference Target	
70133211	NJ0.8-4.5-N	NC	0.8 mm	0.56 mm	4.5 x 4.5 x 1 mm ³ , Fe 360
70133075	NJ0.8-5GM-N	NC	0.8 mm	0.56 mm	4.5 x 4.5 x 1 mm ³ , Fe 360
70133076	NJ0.8-5GM-N-5M	NC	0.8 mm	0.56 mm	4.5 x 4.5 x 1 mm ³ , Fe 360
70133324	NJ0.8-5GM-N-10M	NC	0.8 mm	0.56 mm	4.5 x 4.5 x 1 mm ³ , Fe 360
70133025	NJ1.5-6.5-N	NC	1.5 mm	1.05 mm	6.5 x 6.5 x 1 mm ³ , Fe 360
70133218	NJ1.5-6.5-N-15M	NC	1.5 mm	1.05 mm	6.5 x 6.5 x 1 mm ³ , Fe 360
70133219	NJ1.5-6.5-N-5M	NC	1.5 mm	1.05 mm	6.5 x 6.5 x 1 mm ³ , Fe 360
129729	NJ1.5-6.5-N-Y10514	NC	1.5 mm	1.05 mm	6.5 x 6.5 x 1 mm ³ , Fe 360
180670	NJ1.5-6.5-N-Y10514-10M	NC	1.5 mm	1.05 mm	6.5 x 6.5 x 1 mm ³ , Fe 360
70133080	NJ1.5-8GM-N	NC	1.5 mm	1.05 mm	8 x 8 x 1 mm ³ , Fe 360
70133338	NJ1.5-8GM-N-10M	NC	1.5 mm	1.05 mm	8 x 8 x 1 mm ³ , Fe 360
70133339	NJ1.5-8GM-N-5M	NC	1.5 mm	1.05 mm	8 x 8 x 1 mm ³ , Fe 360
70133081	NJ1.5-8GM-N-V1	NC	1.5 mm	1.05 mm	8 x 8 x 1 mm ³ , Fe 360
70133344	NJ1.5-8GM-N-Y18488	NC	1.5 mm	1.05 mm	8 x 8 x 1 mm ³ , Fe 360
70133192	NJ2-11-N	NC	2.0 mm	1.40 mm	11 x 11 x 1 mm ³ , Fe 360
70133021	NJ2-11-N-G	NC	2.0 mm	1.40 mm	11 x 11 x 1 mm ³ , Fe 360
70133194	NJ2-11-N-G-15M	NC	2.0 mm	1.40 mm	11 x 11 x 1 mm ³ , Fe 360
70133195	NJ2-11-N-G-5M	NC	2.0 mm	1.40 mm	11 x 11 x 1 mm ³ , Fe 360
70133049	NJ2-12GK-N	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360
70133234	NJ2-12GK-N-5M	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360
70133050	NJ2-12GM-N	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360
70133236	NJ2-12GM-N-10M	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360

106575, SJ2-N, PF 02-4-13 R008 V1 R1.12



Part No.	Product Name	Function ¹⁾	S _n	Sar	Reference Target		
70133237	NJ2-12GM-N-25M	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133238	NJ2-12GM-N-5M	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133051	NJ2-12GM-N-V1	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133090	NJ2-V3-N	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133092	NJ2-V3-N-0.075M	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133094	NJ2-V3-N-V5	NC	2.0 mm	1.40 mm	12 x 12 x 1 mm ³ , Fe 360		
70133052	NJ4-12GK-N	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133241	NJ4-12GK-N-10M	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133243	NJ4-12GK-N-5M	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133053	NJ4-12GM-N	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133249	NJ4-12GM-N-10M	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133250	NJ4-12GM-N-20M	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133251	NJ4-12GM-N-5M	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133253	NJ4-12GM-N-V1	NC	4.0 mm	2.80 mm	12 x 12 x 1 mm ³ , Fe 360		
70133204	NJ5-11-N-15M	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		
70133205	NJ5-11-N-5M	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		
70133022	NJ5-11-N-G	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		
70133207	NJ5-11-N-G-10M	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		
70133208	NJ5-11-N-G-5M	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		
70133210	NJ5-11-N-G-6M	NC	5.0 mm	3.50 mm	15 x 15 x 1 mm ³ , Fe 360		

¹⁾ NC = normally closed (break)

3 Safety Function

The safe state is reached when the active face is covered with a target (actuator element, damping material) within the assured release distance s_{ar} . In this case the sensor is in the high impedance state ('off state', I < 1.2 mA). It is important that the gap size between the target and the active face of the sensor is smaller than s_{ar} .

The nominal sensing distance s_n and therefore the assured release distance s_{ar} depend on the dimensions and the material of the target.

If customized targets are used it must be ensured that the distance between the damping material and the active face of the sensor is closer than 0.7 times the individual measured real sensing distance.

This evaluation is only valid for using amplifiers/safety functions that rely on the 'off state' as safe state.

Sensor respective amplifier output	Sensor condition				
ICIN State (IOW IMPEGANCE)	active face uncovered (target not present) and sensor functioning				
Off state (high impedance, safe state)	active face covered (target present) or sensor defective				



4 Safety Characteristic Values

Parameter	Symbol	Condition	Value	Unit
Туре			Α	
Hardware Fault Tolerance	HFT		0	
Safe Failure Rate	λsafe		17.7	FIT
No Effect Failure Rate	λno effect		4.42	FIT
Dangerous Failure Rate	λdangerous		6.91	FIT
Total Failure Rate	$\lambda_{ ext{total}}$		29.0	FIT
Total Safe Failure Rate	λs		22.1	FIT
Total Dangerous Failure Rate	λD		6.91	FIT
Safe Failure Fraction	SFF		76.19	%
Mean Time to Failure	MTTF		3.45E+07	h
Average Probability of Failure on Demand	PFDavg 1)	$T_1 = 1$ year	3.02E-05	
Average Probability of Failure on Demand	PFDavg 1)	$T_1 = 2$ years	6.05E-05	
Average Probability of Failure on Demand	PFDavg 1)	$T_1 = 5$ years	1.51E-04	
Probability of Dangerous Failure per Hour	PFH ¹⁾		6.91E-09	1/h
Safety Integrity Level	SIL		2	
Useful lifetime (Mission Time T_M)			20	years
Diagnostic Coverage	DC		0	%

^{1) 1001} structure

5 Conditions and Assumptions

The following assumptions have been made during the Failure Mode Effect and Diagnostic Analysis:

- Failure rates are based on the Siemens standard SN 29500.
- Failure rates are constant, wear is not included.
- Propagation of failures is not relevant.
- All component failure modes are known (Type A).
- PFD and PFH values are calculated for use in a 1oo1 structure.
- The repair time after a safe failure is 8 hours.
- The average temperature over a long period of time is 40 °C.
- The stress levels are average for an industrial environment and can be compared to the Ground Fixed classification of MIL-HDBK-217F. Alternatively, the assumed environment is similar to IEC 60645-1, Class C (sheltered location) with an average temperature over a long period of time of 40 °C.
- For the high impedance state the object is within the assured release distance ($s < s_{ar}$).
- The 2-wire connection cable between the sensor and the switching amplifier must meet the qualities as follows: Line resistance $R_{\text{series}} < 50~\Omega$ (both leads in series); Insulation resistance $R_{\text{insulation}} > 1~\text{M}\Omega$, as stated in IEC 60947-5-6:1999 and EN 60947-5-6:2000 (NAMUR). The wires must be isolated from any other circuit.
- The products are designed for a useful lifetime of 20 years regarding constant failure rates of its components. Nonetheless, this can be reduced if the device is driven under harsh working conditions with either excessive mechanical stress (vibration), higher average ambient temperature than assumed or prevalent substantial temperature cycles.
- The sensor is operated within the limits given in its datasheet.
- The sensor is connected to a NAMUR interface in accordance with EN 60947-5-6:2000 or IEC 60947-5-6:1999 that relies on the high impedance state ("off state") of the sensor as safe state and is qualified for SIL 2 applications.



6 Definitions

The following definitions for the failure of the product were considered.

Application according to EN 60947-5-6:2000 or IEC 60947-5-6:1999 (DC interface for proximity sensors and switching amplifiers (NAMUR)):

Safe State The fail-safe state is defined as the output being below 1.2 mA (high impedance).

Safe Failure Failure that causes the sensor current consumption to go to the defined fail-safe state

without a demand from the process.

Dangerous Failure Failure leading to an output current above 1.2 mA when he target is within the assured

release distance (i.e. being unable to go to the defined fail-safe state).

"No Effect" Failure of a component that is part of the safety function but has no effect on the safety

function. For the calculation of the SFF it is treated like a safe undetected failure.

For the calculation of the Safe Failure Fraction (SFF) the following has to be noted:

 $\lambda_{\text{total}} = \lambda_{\text{safe}} + \lambda_{\text{dangerous}} + \lambda_{\text{no}}$ effect

 $SFF = 1 - \lambda_{dangerous} / \lambda_{total}$

The failure categories listed above expand on the categories listed in IEC 61508:2000 which are only safe and dangerous. It is important to realize that the "no effect"-failures are included in the safe failure category according to IEC 61508:2000.

Note that these failures on their own will not affect system reliability or safety, and should not be included in spurious trip calculations.

Although the safety characteristic values of the sensor are within the allowed range for SIL 2 according to IEC 61508:2000 it depends on the failure rates of the other devices in the safety loop whether a SIL 2 safety function can be implemented.

Reg. Nr. 000760 QM15

Signature of manufacturer:

Function of the signer:

Date:

ppa. Wolfgang Helm

Director Business Unit Sensors Factory Automation

July 2021

i. V. Ulrich Ehrenfried

Head of Innovation Unit Electromagnetic Sensors Factory Automation



