

Issued 10 May 2018 Page 1 of 5

1 EU - TYPE EXAMINATION CERTIFICATE

Safety Device, Controlling Device or Regulating Device intended for use outside a potentially explosive atmosphere 2 but required for or contributing to the safe functioning of Equipment and Protective Systems with respect to the risks of explosion

Directive 2014/34/EU

- 3 EU - Type Examination Certificate Baseefa11ATEX0021X - Issue 1 Number:
- In accordance with Article 41 of Directive 2014/34/EU, EC-Type Examination Certificates referring to 94/9/EC that were in 3.1 existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Supplementary Certificates to such EC-Type Examination Certificates, and new issues of such certificates, may continue to bear the original certificate number issued prior to 20 April 2016.

Product: Voltage Repeater Type HiC2095 / HiD2096

5 Manufacturer: Pepperl + Fuchs GmbH

Lilienthalstrasse 200, 68307 Mannheim, Germany Address: 6

- This re-issued certificate extends EC Type Examination Certificate No. Baseefa11ATEX0021X to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.
- SGS Baseefa, Notified Body number 1180, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament 8 and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. See Certificate History

Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0:2012+A11:2013 EN 60079-11:2012

except in respect of those requirements listed at item 18 of the Schedule.

- If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use 10 specified in the schedule to this certificate.
- This EU TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further 11 requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- 12 The marking of the product shall include the following:

II (1) G [Ex ia Ga] IIC $(-20^{\circ}\text{C} \le \text{Ta} \le +60^{\circ}\text{C})$

II (1) D [Ex ia Da] IIIC $(-20^{\circ}\text{C} \le \text{Ta} \le +60^{\circ}\text{C})$

I (M1) [Ex ia Ma] I $(-20^{\circ}C \le Ta \le +60^{\circ}C)$

SGS Baseefa Customer Reference No. 0808

Project File No. 17/0608

This document is issued by the Company subject to its General Conditions for Certification Services accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and the Supplementary Terms and Conditions accessible at http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Baseefa Limited

Rockhead Business Park, Staden Lane, Buxton, Derbyshire SK17 9RZ Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601 e-mail baseefa@sgs.com web site www.sgs.co.uk/sgsbaseefa Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65 3EN

R S SINCLAIR TECHNICAL MANAGER On behalf of SGS Baseefa Limited

BAS-CERT-040 Issue 1



13 Schedule

Certificate Number BaseefallATEX0021X – Issue 1

15 Description of Product

The Voltage Repeater Type HiC2095 / HiD2096 is designed to transfer a signal from a hazardous area to unspecified apparatus located in a non-hazardous area. The hazardous area circuit is galvanically isolated from the non-hazardous area circuit using transformers and the voltage and current appearing at the hazardous area connection pins is limited to intrinsically safe levels.

The Voltage Repeater Type HiC2095 / HiD2096 comprises a number of electronic components including two (HiC2095) or four (HiD2096) isolating transformers, fuses, zener diodes and resistors all mounted on a single printed circuit board and housed in a plastic enclosure with two polarised sockets in the base of the enclosure for hazardous and non-hazardous area connections via a terminal backplane and are suitable for direct insertion into termination boards series HiC (CESI06ATEX022) or HiD (CESI02ATEX086) or similar ATEX-certified Pepperl + Fuchs boards. LED indication is provided for power-on status.

The HiC2095 is a single channel repeater and the HiD2096 is a two channel repeater.

Input / Output Parameters

HiC2095

14

Non-Hazardous Area Connector(s)

Power Supply: SL1, pins 1a[-] / 1b[-] w.r.t. pins 2a[+] / 2b[+]

 $U_{\rm m} = 253 {\rm V r.m.s.}$

The circuit connected to the power supply pins is designed to operate from a d.c. supply voltage of up to 30V.

Output: SL1, pins 7a[-] & 8a[+]

 $U_m = 253 \text{V r.m.s.}$

The circuit connected to the output is designed to operate from a d.c. supply of up to 30V.

Hazardous Area Connector(s)

Input: SL2 pins 5a, 1b, 7a, 5b, 1a, 7b

 $U_{0} = 26.4V$ $C_{i} = 0$ $I_{0} = 93 \text{mA}$ $L_{i} = 0$ $P_{0} = 583 \text{mW}$

Input: SL2 pins 1a, 7b, 5b, 5a

 $U_{o} = 25.2V$ $C_{i} = 0$ $I_{o} = 93\text{mA}$ $L_{i} = 0$ $P_{o} = 583\text{mW}$

BAS-CERT-040 Issue I



Issued 10 May 2018 Page 3 of 5

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area load connected to the hazardous area connections of the apparatus must not exceed the following values:

GROUP	CAPACITANCE	INDUCTANCE	OR	L/R RATIO
	(µF)	(mH)		(µH/ohm)
IIC	0.096	4.11		54
IIB / IIIC	0.74	16.44		216
IIA	2.48	32.88		433
I	3.93	53.95		710

The above parameters apply when one of the two conditions below is given:

- the total L_i of the external circuit (excluding the cable) is < 1% of the L_0 value or
- the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total L_i of the external circuit (excluding the cable) $\geq 1\%$ of the L_o value and
- the total C_i of the external circuit (excluding the cable) $\geq 1\%$ of the C_o value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu F$ for Groups I, IIA & IIB / IIIC and 600nF for Group IIC.

HiD2096

Non-Hazardous Area Connector(s)

Power Supply: SL1, pins 1a[-] / 1b[-] w.r.t. pins 2a[+] / 2b[+]

$$U_m = 253 V r.m.s.$$

The circuit connected to the power supply pins is designed to operate from a d.c. supply voltage of up to 30V.

Output: SL1, pins 7a[-] & 8a[+] (Ch 1) and 9a[-] & 10a[+] (Ch 2)

$$U_m = 253 V r.m.s.$$

The circuit connected to the output is designed to operate from a d.c. supply of up to 30V.

Hazardous Area Connector(s)

Input: SL2 pins 5a, 7a, 5b, 7b (Ch 1) and 1a, 3b, 3a, 1b (Ch 2)

$$U_{\rm o} = 26.4 \rm V$$

$$C_{\rm i} = 0$$

$$I_{\rm o} = 93 \,\mathrm{mA}$$

$$L_{\rm i} = 0$$

 $P_0 = 583 \text{mW}$

Input: SL2 pins 7b, 5b, 5a (Ch 1) and 1b, 3a, 1a (Ch 2)

$$U_{\rm o} = 25.2 {\rm V}$$

$$C_i = 0$$

 $I_0 = 93 \text{mA}$

$$L_{\rm i} = 0$$

 $P_{\rm o} = 583 \,\mathrm{mW}$

The capacitance and either the inductance or inductance to resistance ratio (L/R) of the hazardous area load connected to the hazardous area connections of the apparatus must not exceed the following values:

GROUP	CAPACITANCE	INDUCTANCE	OR	L/R RATIO
	(µF)	(mH)		(µH/ohm)
IIC	0.096	4.11		54
IIB / IIIC	0.74	16.44		216
IIA	2.48	32.88		433
I	3.93	53.95		710



Issued 10 May 2018 Page 4 of 5

The above parameters apply when one of the two conditions below is given:

- the total L_i of the external circuit (excluding the cable) is < 1% of the L_0 value or
- the total C_i of the external circuit (excluding the cable) is < 1% of the C_o value.

The above parameters are reduced to 50% when both of the two conditions below are given:

- the total L_i of the external circuit (excluding the cable) $\geq 1\%$ of the L_0 value and
- the total C_i of the external circuit (excluding the cable) $\geq 1\%$ of the C_o value.

Note: the reduced capacitance of the external circuit (including cable) shall not be greater than $1\mu F$ for Groups I, IIA & IIB / IIIC and 600nF for Group IIC.

16 Report Number

See Certificate History

17 Specific Conditions of Use

1. The socket connections at the base of the enclosure must be afforded a degree of protection of at least IP20 when installed.

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

Clause	Subject	Compliance
1.2.7	LVD type requirements	Manufacturer responsibility
1.2.8	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
1.4.1	External effects	User/Installer responsibility
1.4.2	Aggressive substances, etc.	User/Installer responsibility

19 Drawings and Documents

New drawings submitted for this issue of certificate:

Number	Sheet	Issue	Date	Description
HiC2095				
16-0677BS-A	1 of 1	Α	2017-Aug-17	Summary
16-0677BS-00A	1 - 10	Α	2017-Aug-17	Description
16-0677BS-02B	1 of 1	В	2017-Aug-17	Relevant Components
HiD2096				
16-0678BS-A	1 of 1	A	2017-Aug-17	Summary
16-0678BS-00A	1 - 10	A	2017-Aug-17	Description
16-0678BS-02B	1 of 1	В	2017-Aug-17	Relevant Components
Common				
16-0677BS-06A	1 - 6	A	2017-Aug-17	Transformers
16-0677BS-07A	1 & 2	A	2017-Aug-17	PCB Lacquering Details
16-0677BS-10A	1 - 3	Α	2017-Aug-17	Type Label

BAS-CERT-040 Issue 1



Issued 10 May 2018 Page 5 of 5

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
HiC2095				
16-0677BS-03	1 & 2	-	2010-Jul-21	Component Layout
HiD2096				
16-0678BS-03	1 & 2	-	2010-Jul-21	Component Layout
Common				
16-0677BS-01	1 - 3	-	2010-Jul-19	Schematic
16-0677BS-05	1 - 4	-	2010-Jul-19	PCB Layout
16-534-04A	1 & 2	A	2009-Feb-04	HiC/HiD Housing

These drawings are common to Baseefa11ATEX0022X, IECEx BAS 11.0013X and held with IECEx BAS 11.0012X.

20 Certificate History

Certificate No.	Date	Comments	
Baseefal1ATEX0021X	28 February 2011	The release of the prime certificate. The associated test and assessment against the requirements of EN 60079-0:2006, EN 60079-11:2007 & EN 61241-11:2006 is documented in Test Report No. GB/BAS/ExTR11.0020/00. Project File No. 09/0181.	
Baseefal1ATEX0021X Issue 1	10 May 2018	To permit the introduction of alternative components, the use of alternative housing material and additional minor drawing chang Test Report No. GB/BAS/ExTR18.0113/00. Project File No. 17/0608	
For drawings applicable to each issue, see original of that issue.			

BAS-CERT-040 Issue 1