



Member of the FM Global Group

FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 [www.fmaprovals.com](http://www.fmaprovals.com)

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

**WHA-GW-F2D2-0-Aa-Z2-ETH, WirelessHART Gateway**

**WHA-GW-F2D2-0-Aa-Z2-ETH.EIP, WirelessHART Gateway**

NI/II/2/ABCD/T4 Ta = -20°C to 60°C

NI/II, III/2/EFG/T4 Ta = -20°C to 60°C

Class I, Zone 2 AEx nAc nCc IIC T4 Ta = -20°C to 60°C

Class I, Zone 2 AEx nA nC IIC T4 Gc Ta = -20°C to 60°C

a = Cable entry type: S, B or P.

### Equipment Ratings:

Nonincendive for Class I, Division 2, Groups A, B, C and D, indoor and outdoor hazardous (Classified) locations, Nonincendive for Class II and III, Division 2, Group E, F and G, indoor and outdoor hazardous (Classified) locations; Class I, Zone 2 AEx nAc nCc IIC indoor and outdoor hazardous (Classified) locations; Class I, Zone 2 AEx nA nC IIC Gc indoor and outdoor hazardous (Classified) locations temperature classification T4 Ta = -20°C to 60°C.

FM Approved for:

Pepperl+Fuchs GmbH  
Mannheim, Germany

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

3042646



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

FM3600	2011
FM3611	2004
FM3810	2005
ANSI/ISA 60079-0	2009
ANSI/ISA 60079-15	2009


Original Project ID: 3042646

Approval Granted: May 16, 2013

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
131008	October 11, 2013		

FM Approvals LLC

  
J.E. Marquedant  
Group Manager, Electrical

11 October 2013  
Date

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

3042646