

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20100930  
**Date** 2021-April-13

**Issued to:** Pepperl+Fuchs SE  
Lilienthalstrasse 200  
Mannheim68307 DE

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page.

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20100930  
**Date** 2021-April-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

USL, CNL Associated Apparatus for use in Unclassified Locations

Models HiCT followed by B or F; followed by 08, 16, or 32; followed by three alphanumeric characters; may be followed by two alphanumeric characters; may be followed by up to six alphanumeric characters; followed by two to four alphanumeric characters; followed by CC, SC, SP, PL or PF; may be followed by up to six alphanumeric characters, may be followed by Y plus one numeric character. Termination Boards providing intrinsically safe circuits for use in hazardous locations, Class I, Group A, B, C, and D; Class II, Groups E, F, and G; Class III when installed in accordance with Control Drawing no. 116-0327.


USL [AEx ia] IIC

CNL [Ex ia] IIC

Models HiCT followed by B or F; followed by 08, 16, or 32; followed by three alphanumeric characters; may be followed by two alphanumeric characters; may be followed by up to six alphanumeric characters; followed by two to four alphanumeric characters; followed by CC, SC, SP, PL or PF; may be followed by up to six alphanumeric characters, may be followed by Y plus one numeric character. Termination Boards providing intrinsically safe circuits for use in Class I, Zone 0, Group IIC Hazardous Locations when installed in accordance with Control Drawing no. 116-0327.

USL, CNL Associated Apparatus for use Class I, Division 2, Groups A, B, C and D Hazardous Locations

Models HiCTB08-SCT-44C-SC-RA, HiCTB16-SCT-44C-SC-RA, HiCTB16-SDC-24C-SC-RA, HiCTF16-HON-FC-RIO16-SD-PF and HiCTF16-HON-SC-UNI16-SD-PF Termination Boards providing intrinsically safe circuits for use in hazardous locations, Class I, Group A, B, C, and D; Class II, Groups E, F, and G; Class III when installed in accordance with Control Drawing no. 116-0327



Bruce Mahrenholz, Director North American Certification Program

UL LLC




Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20100930  
**Date** 2021-April-13

## Standard(s) for Safety

Standard No. UL 913, 7th Ed., Rev. 2011-09-23, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations  
Standard No. UL 60079-0, 5th Ed., Explosive atmospheres – Part 0: Equipment – General Requirements  
Standard No. UL 60079-11, 5th Ed., Explosive Atmospheres – Part 11: Equipment Protection by Intrinsic Safety “i”  
Standard No. CAN/CSA C22.2 No. 157-92, Reaffirmed 2012, Intrinsically Safe and Non-incendive Equipment for Use in Hazardous Locations  
Standard No. CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres — Part 0: Equipment — General requirements  
Standard No. CAN/CSA-C22.2 No. 60079-11:11, Explosive atmospheres — Part 11: Equipment protection by intrinsic safety “i”  
UL 121201 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS- Edition 9 - Issue Date 2017/09/15  
CSA C22.2 NO. 213 NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS- Edition 3 - Issue Date 2017/09/01  
Standard No. UL 61010-1, 2nd Edition, revised October 28, 2008, Electrical Equipment for Measurement, Control, and Laboratory Use; Part 1: General Requirements  
Standard No. CSA C22.2 No. 61010-1, 2nd Edition, revised October 1, 2008, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use — Part 1: General Requirements



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

