




Type Examination Certificate **CML 17ATEX3030X Issue 3**

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Smart Transmitter Isolator Types KFD2-STC(V)5-Ex1.2O... and KFD2-STC(V)5-Ex2...**
- 3 Manufacturer **Pepperl+Fuchs SE**
- 4 Address **Lilienthalstrasse 200
68307 Mannheim
Germany**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 67386717, Koopvaardijweg 32, 4906CV Oosterhout, The Netherlands, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II of Directive 2014/34/EU.
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Annex VIII apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN IEC 60079-7:2015+A1:2018

- 10 The equipment shall be marked with the following:



Ex ec IIC T4 Gc

Ta = -20 °C to +70 °C

Note: An upper ambient temperature within the range +40 °C to +70 °C may be marked





CML 17ATEX3030X
Issue 3

11 Description

The Smart Transmitter Isolator Type KFD2-STC(V)5-Ex1.2O... and KFD2-STC(V)5-Ex2... are Associated Apparatus Transmitter Power Supplies that transfer monitoring signals from a hazardous area to a safe area and communication signals in both directions. The Safe Area connections are the Power Supply and Outputs. The Hazardous Area Connections (Input Circuits) are for Sink Input, Source Input or Three Wire Input.

The input circuits are galvanically isolated from the output circuits by transformers. The voltage and current limitation for the input circuits are achieved with zener diodes and current limiting resistors. The circuits are located on a single printed circuit board (PCB).

The polymeric enclosure is suitable for mounting on a DIN rail. It provides an environmental rating of IP 20 and is required to be installed in an enclosure or area with a control of pollution access. When installed in a Zone 2 area the Smart Transmitter Isolator must also be installed in a suitably certified enclosure providing an ingress protection of IP54 minimum. Field wiring connections to the device are by colour coded pluggable connectors or powered from pluggable DIN rail connection

Intrinsically safe connections are provided for current or voltage signals and these are covered by a separate certificate.

Nomenclature:

Smart Transmitter Isolator Type KFD2-STC(V)5-Ex2...

Smart Transmitter Isolator Type KFD2-STC(V)5-Ex1.2O...

KFD2-ST Smart Transmitter

Followed by one of the options:

C Current source/sink

V Voltage

Followed by one of the options:

5-Ex1.2O Single hazardous area input/Dual non-hazardous area output.

5-Ex2 Dual hazardous area input/Dual non-hazardous area output.

Followed by one of the options:

-1 5 Volt – used with “V”

-2 10 Volt – used with “V”

.H Higher field voltage

.NCL No current limit

-Y1...n Customised version - does not affect intrinsic safety

-... Customised version - combination of numbers/letters does not affect safety



CML 17ATEX3030X
Issue 3

Rating

All models have the following ratings:

KFD2-STC(V)5-Ex2... & KFD2-STC(V)5-Ex1.2O...	
Connection(s):	Terminals 14, 15 and Power Rail 1,2
Operating Supply Voltage:	18 Vdc to 30 Vdc
Maximum Power:	
- KFD2-STC5-Ex1.2O	≤ 1.7 W
- KFD2-STC5-Ex2	≤ 2.6 W
Maximum Voltage (Um):	250 Vac

Variation 1

This variation introduces the following modifications:

- i. Minor changes to PCB 16-1136CM-05

Variation 2

This variation introduces the following modifications:

- i. To update the certificate to the latest editions of the standards.
- ii. To update the company name from Pepperl+Fuchs GmbH to Pepperl+Fuchs SE
- iii. Offset calibration capability implemented.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	20 Apr 2017	R1616A/00	Issue of Prime Certificate
1	13 Apr 2108	R11656A/00	Introduction of Variation 1
2	07 Mar 2019	R12226A/00	Transfer of Certificate to CML BV
3	17 Nov 2023	R16865A/00	Introduction of Variation 2

Note: Drawings that describe the equipment or component are listed in the Annex.

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated.



**CML 17ATEX3030X
Issue 3**

14 Specific Conditions of Use (Special Conditions)

The following conditions relate to safe installation and/or use of the equipment.

- i. The equipment shall be installed in an enclosure that provides a degree of protection not less than IP54 in accordance requirements of EN 60079-0 unless the equipment is intended to be afforded an equivalent degree of protection by location. In addition, the pollution level shall be limited to pollution degree 2 or better as defined in IEC 60664-1 (Pollution degree 2 can be achieved when the installation is in a controlled environment with suitably controlled condensation or airborne pollution).
- ii. For some types of enclosure, additional certification will be required to permit the installation of the module within the enclosure. Reference should be made to the enclosure certificate. The installer shall ensure that the maximum ambient temperature of the module when installed is not exceeded.
- iii. When the device is mounted in a zoned area, connection and disconnection whilst live is only permitted if the potentially explosive atmosphere is shown to be absent