



# Mining And Surface Certification (Pty) Ltd

2015/021934/07



**Certificate Number:** MASC MS/17-0857  
**Issue:** 5 August 2021  
**Expire:** 23 July 2024  
**Page:** 1 of 4

## IA – CERTIFICATE

(Supplement 2: Reviewed by MASC as per ARP 0108)

IN TERMS OF REGULATION 21.17.2 OF THE MINERALS ACT (INCORPORATION THE MINE HEALTH AND SAFETY ACT) AND REGULATION 9 (1) OF THE ELECTRICAL MACHINERY REGULATIONS OF THE OCCUPATIONAL HEALTH AND SAFETY ACT

Ex – Type Examination

Certificate number:

**MASC MS/17-0857**

Equipment:

Type KCD0-SD-Ex1.1245\* Transformer Isolated Solenoid Driver  
(See “Conditions of Certification”)

Serial No:

Requested by:

Pepperl+Fuchs (Pty) Ltd

Address:

1st fl Zerwick Forum  
8 Glen Eagle Office Park  
Cnr Monument Rd and Braambos St  
Glen Erasmia,  
Kempton Park 1619  
South Africa

Manufacturer:

Pepperl+Fuchs SE

Address:

Lilienthalstrasse 200  
68307 Mannheim  
Germany

Additional Manufacturing location(s):

Pepperl + Fuchs (Manufacturing) PTE LTD

Address:

18 Ayer Rajah Crescent  
Singapore 139942  
Singapore

Additional Manufacturing location(s):

PT. Pepperl + Fuchs

Bintan

SD 56, 57 Lobam, Bintan Industrial Estate

IND-Pulau Bintan

Riau Indonesia

### DESCRIPTION:

The Type KCD0-SD-Ex1.1245\* Transformer Isolated Solenoid Driver is designed to transfer current from unspecified apparatus located in the non-hazardous area to the hazardous area. The voltage and current passed to the hazardous area are limited to intrinsically safe levels and have linear characteristics. The hazardous area circuit is galvanically isolated from the non-hazardous area circuit using transformers.

The Type KCD0-SD-Ex1.1245\* Transformer Isolated Solenoid Driver comprise a number of electronic components, including an isolating transformer, fuses, zener diodes and resistors all mounted on a single printed circuit board and housed in a plastic enclosure with polarized plug-in terminals or optional spring terminals (.SP types only) for hazardous and non-hazardous area connections. LED indication is provided for channel status.

**/.** The variants...

This document may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.

This document will not be supported by MASC for certification purposes outside the borders of South Africa.

Mining And Surface Certification (Pty) Ltd Reg No: 2015/021934/07

Directors: Roelof Viljoen & Francois du Toit

Unit #5, Lelyta Park, 45 Jurg Avenue, Hennospark Ext 87, Centurion, 0157 ♦ P.O. Box 14344, Clubview, 0014

Tell: 012 653 2959 ♦ Fax: 086 605 8568

e-mail: [info@masc-ex.co.za](mailto:info@masc-ex.co.za)

**IA CERTIFICATE NUMBER: MASC MS/17-0857**  
**Type KCD0-SD-Ex1.1245\* Transformer Isolated Solenoid Driver** Page 2 of 4

---

The variants covered by this certificate are as follows:

KCD0-SD-Ex1.1245  
KCD0-SD-Ex1.1245.SP  
KCD0-SD-Ex1.1245-Y\*  
KCD0-SD-Ex1.1245.SP-Y\*

Type KCD0-SD-Ex1.1245 Transformer Isolated Solenoid Driver  
Non-Hazardous Area Terminals 5 & 6

$U_m = 253V$  r.m.s

The circuit connected to non-hazardous area terminals 5 & 6 is designed to operate from a d.c. supply voltage up to 35V.

Hazardous Area Terminals 1 w.r.t. 2

$U_o = 25.5V$        $C_i = 0$   
 $I_o = 110mA$      $L_i = 0$   
 $P_o = 693mW$

The capacitance and either the inductance or the inductance to resistance ratio (L/R) of the load connected to the output terminals must not exceed the following values:

GROUP	CAPACITANCE in $\mu F$	INDUCTANCE OR in mH	L/R RATIO in $\mu H/\Omega$
IIC	0.107	2.94	51
IIB	0.82	11.75	205
IIA	2.90	23.50	410
I	4.15	38.56	673

Note: The above load parameters apply where:

1. The external circuit contains no combined lumped inductance  $L_i$  and capacitance  $C_i$  greater than 1% of the above values.
- or
2. The inductance and capacitance are distributed as in a cable.
- or
3. The external circuit contains either only lumped inductance or lumped capacitance in combination with a cable.

In all other situations e.g. the external circuit contains combined lumped inductance and capacitance, up to 50% of each of the L and C values is allowed.

**MARKING:**

BASEEFA marking remains applicable. The following MASC Certificate number (IA number) must be additionally applied to the equipment.

IA No:                    MASC MS/17-0857

**/ . COMPLIANCE...**

This document may only be reproduced in full.  
This certificate is not transferable and remains the property of the issuing body.  
This document will not be supported by MASC for certification purposes outside the borders of South Africa.

**COMPLIANCE:**

The equipment as described above and in MASC letter 17-0857 is hereby certified "Explosion Protected" [Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I (-20°C ≤ Ta ≤ +60°C) and is suitable for use in hazardous locations as stated below and as tested, assessed and inspected in accordance with the relevant requirements of SANS / IEC Standards:

**The evaluation was conducted according to the requirements of:**

- i) SANS (IEC) 60079-0 : 2012 "Explosive atmospheres – Part 0: Equipment — General requirements"**
- ii) SANS (IEC) 60079-11 : 2012 "Explosive atmospheres – Part 11: Equipment protection by intrinsic safety 'i'"**

Location	Zone *0, 1 & 2 Zone *20, 21 & 22	Gas Surface / Mining (As Applicable) Dust (As Applicable)
Hazard Frequency	---	Continuous as could occur under normal operating conditions in hazardous area (*Outputs only)
Environment	Group I Group IIC Group IIIC	Methane and Coal dust (As Applicable) Propane to Hydrogen / Acetylene (As Applicable) Dust (Metallic & non-metallic) (As Applicable)
Service/Ambient Temperature	-20°C to +60°C	

***The use of apparatus in hazardous locations is subject to the following provisions as applicable, which shall be adhered to:***

- i. SANS 10086 requirements;
- ii. Any conditions mentioned in the above document;
- iii. Codes of Practice enforced in terms of Regulations 21.17.2 of Minerals Act, by Chief Inspector of Mines;
- iv. Any restrictions and conditions enforced by Chief Inspectors of Mines, Principal Inspector (Group I equipment) of Chief Inspector of Factories (Group II equipment);
- v. Any relevant requirements of the MHS Act or the OHS Act.

**CONDITIONS OF MANUFACTURE:**

- None

**SPECIAL CONDITIONS OF USE (X):**

- None

**/I. CONDITIONS...**

This document may only be reproduced in full.  
This certificate is not transferable and remains the property of the issuing body.  
This document will not be supported by MASC for certification purposes outside the borders of South Africa.

**CONDITIONS OF CERTIFICATION:**

1. This Certificate remains valid based on a three yearly review covered by an official MASC letter.
2. The apparatus must be additionally marked with the MASC marking details above.
3. This approval only covers the equipment as certified above and does not include any scheduled additions or variations / amendments / new issues to the certificate(s), made after the above date.
4. The equipment does not need to be re-tested when used on the conditions and with such restrictions as prescribed by BASEEFA and in this approval.
5. The BASEEFA certification must remain valid.
6. The extent of the requirements in the ARP 0108 (or regulations) and SANS 10108 on the certification of the equipment must remain unchanged.
7. The Ex quality assurance notification/report for the equipment must remain valid.



**D.P Visser**  
**TECHNICAL SPECIALIST**



**N Viljoen**  
**TECHNICAL OFFICER**

**Mining And Surface Certification**

*This document is issued based on Mining And Surface Certification's Standard Contract terms and conditions available on request.*

*While every endeavour is made to ensure that a test / assessment is representative and accurately performed, and that a report is accurate in the quoted results and conclusions drawn from the test / assessment, MASC or its members/employees shall in no way be liable for any error made in carrying out the test / assessment or for any erroneous statement, whether in fact or in opinion, contained in a report issued pursuant to a test / assessment.*

*MASC takes no responsibility for any non-conformances, exclusions or any results / assessments not in compliance with the standards. By marking the equipment in accordance with the documentation / standard, the manufacturer attests on his own responsibility that the equipment has been constructed in accordance with the applicable requirements of the relevant standards and that the routine verifications and routine tests have been successfully completed and the product complies with the documentation and standard(s).*

*This document is only for use and application in South Africa. It is issued based on National interpretations and accepted practises.*

**This document may only be reproduced in full.**  
**This certificate is not transferable and remains the property of the issuing body.**  
**This document will not be supported by MASC for certification purposes outside the borders of South Africa.**