




Mining And Surface Certification (Pty) Ltd

2015/021934/07

THIS CERTIFICATE IS ISSUED AS AN I.A. CERTIFICATE IN TERMS OF THE MINE HEALTH AND SAFETY ACT, ACT NO 29 OF 1996 (AND REGULATIONS), THE OCCUPATIONAL HEALTH AND SAFETY ACT (ACT 85 OF 1993) AND REGULATION 17 OF THE ELECTRICAL MACHINERY REGULATIONS

IA CERTIFICATE	MASC MS/17-0860	Issue	3
Issue Date	27 March 2023	Expiry Date	27 March 2026
*Based on Certificate No	Baseefa03ATEX0141	Issue / Variations / Amendment	3
Requested by	Pepperl+Fuchs (Pty) Ltd, 8 Glen Eagle Office Park, Koorsboom Ave, Glen Marais, Kempton Park, 1619, South Africa		
Manufacturer	Pepperl+Fuchs SE Lilienthalstrasse 200, 68307 Mannheim Germany		
Description	A Transformer Isolated Loop Powered, Current Separator Type KFD0-CS-Ex*.52 is designed to restrict the transfer of energy from unspecified Non Hazardous Area Apparatus without the need of high integrity earth. The unit is intended to provide a high integrity path from hazardous area ad both a dual and a single channel version is available. The "*" in the type is replaced by a "2" for the dual version and a "1" for the single version channel version. The apparatus is designed for a rated input voltage not exceeding 40V d.c. but the creepage and clearance distances between the non-hazardous and the hazardous area circuitry are acceptable for peal voltage of 375 volts, (253V volts r.m.s.). The apparatus comprises a maximum of two channels, and each channel comprises a transformer and electronic components mounted a printed circuit board and housed with a plastic enclosure which is fitted with terminals for the connection of external equipment.		
Equipment	Transformer Isolated, Loop Powered, Current Separator	Type	KFD0-CS-Ex*.52
MARKING: Original marking as per certificate * remains applicable. IA number to be added.	Type Ex Marking IA Number Warnings	Transformer Isolated Loop Powered Current Separator Type KFD0-CS-Ex*.52 [Ex ia Ga] IIC [Ex ia Da] IIIC [Ex ia MA] I (-20°C ≤ Ta ≤ +60°C) MASC MS/17-0860 (To be additionally marked on equipment) See Base Certificate ** (original marking must be applied)	
Quality Assurance report (QAR) / Notification (QAN):	"It is a requirement under ATEX that all equipment for category 1 and 2 areas must have 3rd party quality assurance from a notified body. This is accepted to cover the equipment's quality requirements."		
Compliance: The equipment as described above has been allocated the rating <u>Explosion Protected 'as above'</u> utilizing the SANS/IEC Standards: <ul style="list-style-type: none"> SANS (IEC) 60079-0: 2012 Equipment - General requirements SANS (IEC) 60079-11: 2012 Equipment protection by intrinsic safety "i" Note: This certificate covers only the listed standards and does not imply compliance to any other standard, related or inferred. It is up to the manufacturer to ensure that the product complies to all relevant standards for the application. 			
Special conditions of safe use "X": <ul style="list-style-type: none"> See "Annex A" below 			
Conditions of manufacture: <ul style="list-style-type: none"> See "Annex A" below 			
 S. Jordaan TECHNICAL SPECIALIST		 C. Welthagen TECHNICAL SPECIALIST	

This certificate covers all units sold as long as the QAR/QAN remains valid.
According to the relevant requirements of the MHS Act and the OHS Act, production units of explosion protected equipment are required to comply with third party quality assurance (an approved mark scheme or batch testing by an accredited test laboratory).

/ . ANNEX A...

Apparatus in hazardous locations is subject to the following provisions as applicable, which shall be adhered to:
SANS 10086 requirements;
Any conditions mentioned in the above report
Any restrictions and conditions enforced by the chief inspector of mines or chief inspector of factories
Any relevant requirements of the MHS Act.

This certificate may only be reproduced in full.
This certificate is not transferable and remains the property of the issuing body

Mining And Surface Certification (Pty) Ltd
Unit 5 Lelyta Park, 45 Jurg Ave, Hennospark Ext 87
Centurion, 0157

IA CERTIFICATE: MASC MS/17-0860
Equipment: Transformer Isolated Loop Powered Current Separator
(Expiry date: 27 March 2026)

Page 2 of 2

ANNEX A

This document is based on and must be read in conjunction with certificate Baseefa03ATEX0141.	
Description (According to Base Certificate *)	
"Refer to description in Base Certificate * (and any applicable schedules/issues/variatioins)."	
Standard compliance	See Base Certificate *
Special conditions of safe use ("X")	None
Conditions of manufacture	None
Conditions of Certification	<ul style="list-style-type: none"> • This IA Certificate covers all units sold from the date of this document to the expiry date of this certificate. • As per ARP 0108 a maximum three yearly review is required on this IA Certificate (expiry is determined as per the QAR/QAN/QMS expiry date). • The apparatus must be additionally marked with the MASC marking details above. • This approval only covers the equipment as certified above and does not include any scheduled additions or variations / amendments / new issues to the certificate(s), made after the above date. • The equipment does not need to be re-tested when used on the conditions and with such restrictions as prescribed by the certificate on which this IA Certificate is based and any other conditions in this IA Certificate. • The certification on which this IA Certificate is based must remain valid. • The extent of the requirements in the ARP 0108 (or regulations), SANS 10108 and any other applicable regulations on the certification of the equipment must remain unchanged. • The Ex quality assurance notification/report for the equipment must remain valid.
Conclusion:	<ul style="list-style-type: none"> • From the above and the selective examination of the documentation, nothing contrary to the requirements of the applicable standards was found, provided that the equipment / component is used as described in the above document / certificate and according to the MASC conditions below. A MASC IA certificate is issued based on the work done as per the Base Certificate *. • The routine tests for production units according to the Base Certificate * must be complied with (if applicable).

This document is issued based on Mining And Surface Certification's Standard Contract terms and conditions available on request.

While every endeavour is made to ensure that a test / assessment / inspection is representative and accurately performed, and that a report / certificate is accurate in the quoted results and conclusions drawn from the test / assessment / inspection, MASC or its directors/employees shall in no way be liable for any error made in carrying out the test / assessment or for any erroneous statement, whether in fact or in opinion, contained in a report / certificate issued pursuant to a test / assessment / inspection.

MASC takes no responsibility for any non-conformances, exclusions or any results / assessments / inspections not in compliance with the standards. By marking the equipment in accordance with the documentation / standard, the manufacturer / applicant attests on his own responsibility that the equipment / installation has been designed and constructed in accordance with the applicable requirements of the relevant standards and documentation, that the routine verifications / routine tests have been correctly completed and the equipment / installation complies with the documentation and standard(s).

This document is only for use and application in South Africa. It is issued based on National interpretations and accepted practices