



Mining And Surface Certification (Pty) Ltd

2015/021934/07

THIS CERTIFICATE IS ISSUED AS AN I.A. CERTIFICATE IN TERMS OF THE MINE HEALTH AND SAFETY ACT, ACT NO 29 OF 1996 (AND REGULATIONS), THE OCCUPATIONAL HEALTH AND SAFETY ACT (ACT 85 OF 1993) AND REGULATION 17 OF THE ELECTRICAL **MACHINERY REGULATIONS**

		Ι.			
IA CERTIFICATE	MASC MS/17-2381X	Issue	3		
Issue Date	30 April 2024	Expiry Date	30 April 2027		
** Based on Certificate No	IECEx BAS 06.0026X	Issue / Variations / Amendment 3			
Requested by	Pepperl+Fuchs (Pty) Ltd				
	Zerwick Forum, 8 Glen Eagle Office Park Cnr Monument Rd and Braambos St,				
	Glen Erasmia, Kempton Park 1619, South Africa				
Manufacturer	Pepperl+Fuchs SE				
	Lilienthalstrasse 200, 68307 Mannheim, Germany				
Description	The Type HiC282* Switch Amplifiers are designed to transfer digital signals from the hazardous				
	area to unspecified apparatus located in the non-hazardous area. The voltage and current passed				
	to the hazardous area are limited to intrinsically safe levels and have linear characteristics. Up to				
	two hazardous area channels are fitted and are galvanically isolated from the non-hazardous area				
	circuit using transformers.				
	The Type HiC282* Switch Amplifier comprise a number of electronic components, including				
	isolating transformers, fuses, zener diodes and resistors all mounted on a single printed circuit				
	board and housed in a plastic enclosure with two polarised sockets in the base of the enclosure				
	for hazardous and non-hazardous area connections via a terminal backplane. The non-hazardous				
	area connections are via relay contacts with configuration switches allow the setting of the				
	direction of operation and lead monitoring. LED indication is provided for power-on				
	and channel status.				
	There are two models of the Type HiC282* Switch Amplifier, the Type HiC2822 Two Channel				
	Switch Amplifier, and the Type HiC2821 Single Channel Switch Amplifier. The Type HiC2821 is a				
	depopulated version of the HiC2822 with only one hazardous area channel.				
	See **Base certificate Annex for electrical parameters.				
Equipment	Switch Amplifier	Type HiC2	82*		
MARKING:	Type:	Type HiC282* S	Switch Amplifier		
Original marking as per	Ex Marking:	[Ex ia Ga] IIC			
certificate ** remains		Ex ia Daj IIIC			
applicable.		[Ex ia Ma] I			
IA number must be added.		-20°C ≤ Ta ≤ +60°C			
	IA Number:	MASC MS/17-2	381X (To be additiona	lly marked on equipment)	
	Warnings:	See Base Certif	icate ** (original marki	ng must be applied)	
Quality Assurance report (C	DE/PTB/QAR06.0008/20				
Compliance					

Compliance:

The equipment as described above has been allocated the rating Explosion Protected 'as above' utilizing the SANS/IEC Standards:

- SANS (IEC) 60079-0:
 SANS (IEC) 60079-11:
 2009 Equipment General requirements
 Equipment protection by intrinsic safety "i"

Note: This certificate covers only the listed standards and does not imply compliance to any other standard, related or inferred. It is up to the manufacturer to ensure that the product complies to all relevant standards for the application.

Special conditions of safe use "X":

Refer to Annex A below for more details

Conditions of manufacture:

C. WELTHAGEN **TECHNICAL SPECIALIST** **TECHNICAL OFFICER**

This certificate covers all units sold as long as the QAR/QAN remains valid.

According to the relevant requirements of the MHS Act and the OHS Act, production units of explosion protected equipment are required to comply with third party quality assurance (an approved mark scheme or batch testing by an accredited test laboratory).

Apparatus in hazardous locations is subject to the following provisions

as applicable, which shall be adhered to: SANS 10086 requirements;

Any conditions mentioned in the above certificate;

Any relevant requirements of the MHS Act;

Any restrictions and conditions enforced by the chief inspector of mines, principal inspector (Group I equipment) or chief inspector of factories (Group II equipment).

This certificate may only be reproduced in full The certificate is not transferable and remains the property of the issuing body.

IA CERTIFICATE: MASC MS/17-2381X

Equipment: HiC282* Switch Amplifier (Expiry date: 30 April 2027)

Page 2 of 2

ANNEX A

This document is based on and must be read in conjunction with certificate IECEx BAS 06.0026X. Description (According to Base Certificate) **			
Issue	Issue 1: Supplemented for revision as per ARP 0108. Issue 2: Supplemented for review as per ARP 0108. Issue 3: Supplemented for review as per ARP 0108.		
Standard compliance	See Base Certificate **		
Special conditions of safe use ("X")	The socket connections at the base of the enclosure must be afforded a degree of protection of at least IP20 when installed.		
Conditions of manufacture	None.		
Conditions of Certification	 This IA Certificate covers all units sold from the date of this document to the expiry date of this certificate. As per ARP 0108 a maximum three yearly review is required on this IA Certificate (expiry is determined as per the QAR/QAN/QMS expiry date). The apparatus must be additionally marked with the MASC marking details above. This approval only covers the equipment as certified above and does not include any scheduled additions or variations / amendments / new issues to the certificate(s), made after the above date. The equipment does not need to be re-tested when used on the conditions and with such restrictions as prescribed by the certificate on which this IA Certificate is based and any other conditions in this IA Certificate. The certification on which this IA Certificate is based must remain valid. The extent of the requirements in the ARP 0108 (or regulations), SANS 10108 and any other applicable regulations on the certification of the equipment must remain unchanged. The Ex-quality assurance notification/report for the equipment must remain valid. 		
Conclusion:	 From the above and the selective examination of the documentation, nothing contrary to the requirements of the applicable standards was found, provided that the equipment / component is used as described in the above document / certificate and according to the MASC conditions below. A MASC IA certificate is issued based on the work done as per the Base Certificate **. The routine tests for production units according to the Base Certificate ** must be complied with (if applicable). 		

This document is issued based on Mining And Surface Certification's Standard Contract terms and conditions available on request.

While every endeavour is made to ensure that a test / assessment / inspection is representative and accurately performed, and that a report / certificate is accurate in the quoted results and conclusions drawn from the test / assessment / inspection, MASC or its directors/employees shall in no way be liable for any error made in carrying out the test / assessment or for any erroneous statement, whether in fact or in opinion, contained in a report / certificate issued pursuant to a test / assessment / inspection.

MASC takes no responsibility for any non-conformances, exclusions, or any results / assessments / inspections not in compliance with the standards. By marking the equipment in accordance with the documentation / standard, the manufacturer / applicant attests on his own responsibility that the equipment / installation has been designed and constructed in accordance with the applicable requirements of the relevant standards and documentation, that the routine verifications / routine tests have been correctly completed and the equipment / installation complies with the documentation and standard(s).

This document is only for use and application in South Africa. It is issued based on National interpretations and accepted practices.

This document may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.

This document will not be supported by MASC for certification purposes outside the borders of South Africa.