

CERTIFICATE OF COMPLIANCE

Certificate Number E501628
Report Reference E501628- 20190304
Date 2021-SEPTEMBER-17

Issued to: Pepperl+Fuchs SE
Lilienthalstrasse 200
Mannheim 68307 DE

**This is to certify that
representative samples of**

AUXILIARY DEVICES FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: SEE ADDENDUM PAGE

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E501628
Report Reference E501628- 20190304
Date 2021-SEPTEMBER-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Intrinsically safe apparatus for use in Class I, Division 1 Group A, B, C, D; Class II, Division 1, Group E, F, G; and Class III, Division 1

USL – Class I, Zone 0, AEx ia IIC; Zone 20 AEx ia IIIC

CNL – Ex ia IIC Ga; Ex ia IIIC Da

Type code N or NJ, may be followed by C, may be followed by B or N, followed by nominal sensing range in mm, may be followed by sensor diameter in mm, may be followed by plastic enclosure diameter with G letter, may be followed by G, may be followed by M, K or KK, may be followed by length of thread in mm, followed by N, N0 or N1, may be followed by C, G, V or details of max operation temperature for high temperature sensors, may be followed by Y, may be followed by letters and/or numbers up to eight digits, intrinsically safe when installed in accordance with control drawing number 116-0452.

All model names may include any alphanumeric digits at the end, with no effect on construction or intrinsic safety characteristics.

STANDARDS


UL 913 STANDARD FOR INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS

UL 60079-0 EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS

UL 60079-11 EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I"

CSA C22.2 NO. 60079-11:14 EXPLOSIVE ATMOSPHERES — PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I"

CSA C22.2 NO. 60079-0 EXPLOSIVE ATMOSPHERES — PART 0: EQUIPMENT — GENERAL REQUIREMENTS



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

