

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190321-E106378  
**Report Reference** E106378-19960425  
**Issue Date** 2019-MARCH-21

**Issued to:** Pepperl+Fuchs GmbH  
Lilienthalstrasse 200  
68307 Mannheim GERMANY

**This certificate confirms that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See addendum page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**  
**Additional Information:**

See Addendum Page For Standards

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190321-E106378  
**Report Reference** E106378-19960425  
**Issue Date** 2019-MARCH-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Standard(s) for Safety:

Standard No. UL 913, 8th Edition, Rev. 2018/12/10, STANDARD FOR INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS

Standard No. UL 121201, 9th Edition, Rev. 2018/08/31, NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS

Standard No. CAN/CSA C22.2 No. 157-92, Edition 3, Rev. 2003-06-01, INTRINSICALLY SAFE AND NON-INCENDIVE EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS

Standard No. CAN/CSA C22.2 No. 213, Edition 3, Rev. 2017/09/01, NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS

Standard No. UL 61010-1, Edition 2, Rev. 2005/07/22 – SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS

Standard No. CAN/CSA C22.2 NO. 61010-1, Edition 2, Rev. 2008/10/01, SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE — PART 1: GENERAL REQUIREMENTS

USL, CNL Associated Apparatus: Class I, Div. 2, Groups A, B, C and D; Hazardous Locations.

Shunt diode barriers providing intrinsically safe circuits for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; Class III or providing non-incendive circuits for use in Class I, Division 2, Groups A, B, C and D; Class II, Division 2, Groups F and G, and Class III, Division 2, hazardous locations when installed in accordance with Control Drawing No. 116-0139;

Models Z705, Z710, Z710.CL, Z713, Z715, Z715.CL, Z715.1K, Z722, Z722.CL, Z728, Z728.CL, Z728.H, Z755, Z757, Z763, Z764, Z765, Z772, Z778, Z779, Z779.H, Z786, Z787, Z787.H, Z788, Z788.R, Z788.H, Z788.R.H, Z796, Z796.L,

Z805, Z810, Z810.CL, Z813, Z815, Z815.CL, Z815.1K, Z822, Z822.CL, Z828, Z828.CL, Z828.H, Z855, Z857, Z864, Z865, Z872, Z878, Z879, Z879.H, Z886, Z887, Z887.H, Z888, Z888.R, Z888.H, Z888.R.H, Z896, Z896.L,

Z905, Z910, Z915, Z915.1K, Z928, Z954, Z955, Z960, Z961, Z961.H, Z964, Z965, Z966, Z966.H, Z967, Z969, Z972, Z978

Shunt diode barriers providing intrinsically safe circuits for use in Class I, Groups C, D; Class II, Groups E, F, G; Class III and providing non-incendive circuits for use in Class I, Division 2, Groups C and D; Class II, Division 2, Groups F and G, and Class III, Division 2, hazardous locations when installed in accordance with Control Drawing No. 116-0139;

Model Z726



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

