

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160608-E106378  
**Report Reference** E106378-19970520  
**Issue Date** 2016-JUNE-08

**Issued to:** Pepperl+Fuchs Inc  
1600 ENTERPRISE PKWY  
TWINSBURG OH 44087-2202

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS, PROCESS CONTROL  
EQUIPMENT FOR USE IN ZONE CLASSIFIED  
HAZARDOUS LOCATIONS  
Refer to Addendum page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** Refer to Addendum page for Standards  
**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160608-E106378  
**Report Reference** E106378-19970520  
**Issue Date** 2016-JUNE-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## MODELS

ASSOCIATED APPARATUS, CLASS I, DIVISION 2, GROUPS A, B, C AND D HAZARDOUS LOCATIONS

Switch isolators (intrinsic safety barriers - discrete input) providing intrinsically safe circuits for use in Class I, Groups A, B, C, D; Class II, Groups E, F, G; and Class III Hazardous Locations when installed in accordance with Control Drawing No. 116-0145.

Models KFA5-SR2-Ex\*, KFA6-SR2-Ex\*, KFA5-SOT2-Ex\*, KFA6-SOT2-Ex\*, KFD2-SRA-Ex\*, KFD2-SR2-Ex1.W, KFD2-SR2-Ex1.W.LB, KFD2-SR2-Ex2.W, and KFD2-SR2-Ex2.W.SM.

## STANDARDS

ANSI/ISA 12.12.01-2015, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division 1 and 2 Hazardous (Classified) Locations  
C22.2 No. 213-15 "Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division 1 and 2 Locations"  
CSA C22.2 NO. 61010-1-12 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use. Pt. 1, General Requirements  
UL 61010-1 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

