

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20090626  
**Date** 2021-April-13

**Issued to:** Pepperl+Fuchs SE  
Lilienthalstrasse 200  
Mannheim68307 DE

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. UL 913 - Intrinsically Safe Apparatus and  
Associated Apparatus for Use in Class I, II, and III, Division  
1, Hazardous (Classified) Locations.  
Standard No. UL 61010-1 - Electrical Equipment for  
Measurement, Control, and Laboratory Use; Part 1: General  
Requirements.  
Standard No. ANSI/ISA 12.12.01, 2007 - Nonincendive  
Electrical Equipment for Use in Class I and II, Division 2  
and Class III, Divisions 1 and 2 Hazardous (Classified)  
Locations

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE


**Certificate Number** E106378  
**Report Reference** E106378-20090626  
**Date** 2021-April-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

Associated Apparatus for use in Unclassified Locations and Class I, Division 2, Groups A, B, C, and D Hazardous Locations.

USL - Models KFD2-UT2-Ex1\* and KFD2-UT2-Ex2\* (\* = blank or -1) barriers providing intrinsically safe circuits for use in Class I, Groups A, B, C, and D; Class II, Groups E, F, and G; and Class III hazardous locations when installed in accordance with control drawing no. 116-0410.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

