

CERTIFICATE OF COMPLIANCE

Certificate Number E106378
Report Reference E106378-20130719
Date 2021-April-13

Issued to: Pepperl+Fuchs SE
Lilienthalstrasse 200
Mannheim68307 DE

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E106378
Report Reference E106378-20130719
Date 2021-April-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

USL - Associated Apparatus for use in Unclassified Locations or Class I Division 2, Groups A, B, C, D Hazardous Locations, [AEx ia Ga] IIC, [AEx ia Da] IIIC.

CNL - Associated Apparatus for use in Unclassified Locations or Class I Division 2, Groups A, B, C, D Hazardous Locations, [Ex ia Ga] IIC, [Ex ia Da] IIIC.


Model KCD2-STC-EX1.ES, followed by blank or .SP, may be followed by a dash, may be followed by one or two alphanumeric character(s), galvanically isolated barrier provides intrinsically safe outputs for use in Class I, Division 1, Groups A, B, C, D, Class II, Division 1, Groups E, F, G, Class III, Division 1; Class I, Zone 0 and 1, Group IIC and Zone 20 and 21, Group IIIC Hazardous Locations when installed in accordance with manufacturer's control drawing no. 116-0378.

USL, CNL - Class I, Zone 2 AEx ec IIC T4 Gc and Ex ec IIC T4 Gc X

Model KCD2-STC-EX1.ES, followed by blank or .SP, may be followed by a dash, may be followed by one or two alphanumeric character(s).

Standard(s) for Safety:

UL 913 : STANDARD FOR INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS
UL 60079-0 : EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS
UL 60079-7 : EXPLOSIVE ATMOSPHERES - PART 7: EQUIPMENT PROTECTION BY INCREASED SAFETY 'E'
UL 60079-11 : EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY 'I'
UL 121201 : NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS
CSA C22.2 NO. 60079-0 : EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS
CSA C22.2 NO. 60079-7:16 : EXPLOSIVE ATMOSPHERES - PART 7: EQUIPMENT PROTECTION BY INCREASED SAFETY "E"
CSA C22.2 NO. 60079-11:14 : EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I"
CSA C22.2 NO 213 : NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS
UL 61010-1 : Standard for Electrical Equipment For Measurement, Control, and Laboratory Use
CSA/CAN C22.2 No. 61010-1-12 : Standard for Electrical Equipment For Measurement, Control, and Laboratory Use



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>