

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160401-E106378  
**Report Reference** E106378 -20160330  
**Issue Date** 2016-APRIL-01

**Issued to:** Pepperl+Fuchs Inc  
1600 ENTERPRISE PKWY  
TWINSBURG OH 44087-2202

**This is to certify that representative samples of** PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS

USL, CNL Process Control Equipment for use in Hazardous Locations, Class I, Div. 2 Groups A, B, C, and D  
Power Feed modules Models KFD2-EB2, and KFD2-EB2.SP.  
Redundant Power Feed modules Models KFD2-EB2.R4A.B, and KFD2-E2-R4A.B.SP  
Power Rail UPR-03 and UPR-05

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See addendum page for standards  
**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20160401-E106378  
**Report Reference** E106378 -20160330  
**Issue Date** 2016-APRIL-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Standards

Standard No. ANSI/ISA-12.12.01-2015, Issued 2015-08-21, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations  
Standard No. CAN/CSA C22.2 NO. 213-15, Issued 2015-08-21, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations  
UL 61010-1 Safety Requirements For Electrical Equipment For Measurement, Control, and Laboratory Use - Part 1: General Requirements  
CA C22.2 No. 61010-1-12 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use – Part 1: General Requirements



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

