

CERTIFICATE OF COMPLIANCE

Certificate Number E106378
Report Reference E106378-20160330
Date 2022-November-29

Issued to: Pepperl+Fuchs SE
Lilienthalstrasse 200
Mannheim 68307 DE

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 61010-1 and CA C22.2 No. 61010-1-12, Safety Requirements
for Electrical Equipment for Measurement, Control, and
Laboratory Use - Part 1: General Requirements

UL 121201 and CSA C22.2 NO. 213, Nonincendive Electrical
Equipment for Use in Class I And II, Division 2 And Class III,
Divisions 1 And 2 Hazardous (Classified) Locations


Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E106378
Report Reference E106378-20160330
Date 2022-November-29

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product(s):

Process Control Equipment for use in Hazardous Locations, Class I, Div. 2 Groups A, B, C, and D.

Power Feed modules Models KFD2-EB2, and KFD2-EB2.SP.

Redundant Power Feed modules Models KFD2-EB2.R4A.B, and KFD2-EB2-R4A.B.SP.

Power Rail UPR-03 and UPR-05.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

