

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-2016-12-02  
**Date** 2021-October-22

**Issued to:** Pepperl+Fuchs SE  
Lilienthalstrasse 200  
Mannheim 68307 DE

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** SEE ADDENDUM PAGE

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-2016-12-02  
**Date** 2021-October-22

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

**Models:**

Process Control Equipment for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Models LB81; followed by 20, 21, 22, 25, 30 or 35; followed by A.1 or A.2; followed by .EL; followed by any alphanumeric.

Process Control Equipment for use in Class I, Zone 2, A/Ex ec IIC Gc Hazardous Locations.

Models LB81; followed by 20, 21, 22, 25, 30 or 35; followed by A.1 or A.2; followed by .EL; followed by any alphanumeric.

**Standard(s) for Safety:**

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

UL 60079-0, Explosive Atmospheres - Part 0: Equipment - General Requirements

UL 60079-7, Explosive atmospheres - Part 7: Equipment protection by increased safety "e"

UL 61010-1 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS

CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations

CSA C22.2 No. 60079-0, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements

CSA C22.2 No. 60079-7, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e"

CSA C22.2 NO. 61010-1 SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

