





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2021322310003602**

**APPLICANT:** Pepperl+Fuchs SE  
**ADDRESS:** Lilienthalstraße 200, 68307 Mannheim,Germany  
**MANUFACTURER:** Pepperl+Fuchs SE  
**ADDRESS:** Lilienthalstraße 200, 68307 Mannheim,Germany  
**FACTORY:** Pepperl+Fuchs SE  
**ADDRESS:** Lilienthalstraße 200, 68307 Mannheim,Germany

**PRODUCTNAME:** Gateway  
**SERIES,SPECIFICATION,MODEL:** LB81\*.1.EL\* series  
**STANDARDS:** GB 3836.1-2010、 GB 3836.8-2014

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**January 5, 2021

**Valid until:** January 4, 2026

**Date of original certification:**January 5, 2021

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitifias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0004351



# 中国国家强制性产品认证证书



证书编号：2021322310003602

## 附件

产品名称： 网关

型号规格： LB81\*.1.EL\*系列

LB8120.1.EL\*

LB8121.1.EL\*

LB8122.1.EL\*

LB8130.1.EL\*

LB8135.1.EL\*

\*: blank or a combination of tokens, indicating functional information that have no influence on the approvals

防爆标志： Ex nA IIC T4 Gc

使用环境温度： -40°C~+60°C

电气参数：

连接件代码	电气参数(SELV/PELV)	
	电气参数	最高电压 Um
RJ45	EtherNe / RS485	50Vd.c. 35 Va.c.
电源 (X1: 6, 7)	+12V d.c.	30Vd.c.

批 准：



## 上海仪器仪表自控系统检验测试所有限公司