

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20190710  
**Date** 2021-April-13

**Issued to:** Pepperl+Fuchs SE  
Lilienthalstrasse 200  
Mannheim68307 DE

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** See Addendum Page.

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E106378  
**Report Reference** E106378-20190710  
**Date** 2021-April-13

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements


**Product(s):**

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, AEx ec [ja Ga] IIC T4 Gc, and Ex ec [ja Ga] IIC T4 Gc Hazardous Locations.

Models KCD2 followed by -STC or -SCD followed by -Ex1 may be followed by .SP, may be followed by additional alphanumeric characters, providing intrinsically safe circuits for Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III; and Class I, Zone 0, Group IIC hazardous locations when installed in accordance with manufacturer's Control Drawing No. 116-0459.

**Standard(s) for Safety:**

UL 61010-1 & CSA C22.2 NO. 61010-1, SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS  
UL 913, STANDARD FOR INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS  
UL 121201 & C22.2 NO. 213, NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS  
UL 60079-0, EXPLOSIVE ATMOSPHERES - PART 0: EQUIPMENT - GENERAL REQUIREMENTS  
UL 60079-7, STANDARD FOR EXPLOSIVE ATMOSPHERES - PART 7: EQUIPMENT PROTECTION BY INCREASED SAFETY "E"  
UL 60079-11, EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I"  
CSA C22.2 NO. 157-92, INTRINSICALLY SAFE AND NON-INCENDIVE EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS  
CSA C22.2 NO. 60079-0:15, EXPLOSIVE ATMOSPHERES — PART 0: EQUIPMENT — GENERAL REQUIREMENTS  
CSA C22.2 NO. 60079-7:16, EXPLOSIVE ATMOSPHERES - PART 7: EQUIPMENT PROTECTION BY INCREASED SAFETY "E"  
CSA C22.2 NO. 60079-11:14, EXPLOSIVE ATMOSPHERES — PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY "I"



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

