

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge protective devices

Name and address of the applicant

Pepperl+Fuchs SE
Lilienthalstraße 200,
68307 Mannheim, Germany

Name and address of the manufacturer

Pepperl+Fuchs SE
Lilienthalstraße 200,
68307 Mannheim, Germany

Name and address of the factory

PT. Pepperl+Fuchs Bintan
Jl. Asoka SD 56,
Bintan Industrial Estate, Lobam,
29154 Bintan, Indonesia
 Additional Information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Types with xx 12 or 14: Uc = DC 6 V; In = 500 mA
Types with xx 42 or 44: Uc = DC 30 V; In = 500 mA

Trademark / Brand (if any)

PEPPERL+FUCHS

Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

M-LB-21xx; M-LB-21xx.SP; M-LB-Ex-21xx; M-LB-Ex-21xx.SP
xx... 12, 14, 42 or 44

Additional information (if necessary may also be reported on page 2)

--

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-21:2000
IEC 61643-21:2000/AMD1:2008
IEC 61643-21:2000/AMD2:2012

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1035-1 to CTI-CB 1035-4

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

Testing and Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

Digitally signed by W. Martin
Email=w.martin@ove.at

Date: 2020-07-24



Signature: Dipl.-Ing. W. Martin

Additional factory:

Pepperl+Fuchs Asia Pte Ltd.
18 Ayer Rajah Crescent,
139942 Singapore, Singapore

Additional information (if necessary)

Date: 2020-07-24



Digitally signed by W. Martin
Email=w.martin@ove.at

Signature: Dipl.-Ing. W. Martin