



EU Type Examination Certificate CML 20ATEX3118U Issue 0

- 1 Components intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Component **SR Ex e Enclosures**
- 3 Manufacturer Pepperl+Fuchs SE
- 4 Address Lilienthalstrasse 200
68307 Mannheim
Germany
- 5 The component is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Koopvaardijweg 32, 4906CV Oosterhout The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 The 'U' suffix after the certificate number indicates that the component is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-7:2015+A1:2018

EN 60079-31:2014

- 10 The equipment shall be marked with the following:



II 2 G D

Ex eb IIC Gb

Ex tb IIIC Db

Ts= -60°C to +120°C



CML 20ATEX3118U
Issue 0

11 Description

The SR Ex e enclosures are square or rectangular fabricated steel increased safety enclosures with covers secured by either M6 hexagon head screws or quarter turn locks. The cover fasteners along one edge may be replaced by hinges, and quarter turn locks are always used in conjunction with hinges. Sealing to IP66 between the body and cover is achieved using a silicone gasket.

Cable entries to the enclosures may be made with suitably certified cable entry devices, direct to the enclosure in the case of the smaller SRS types, or via gland plates fitted to the sidewalls in the case of the larger SRM/L/X types.

All SR types may be fitted with an internal/external earth stud to accommodate earthing or equipotential bonding connections.

The SR Ex e enclosures may be joined using a connecting flange, or to an Ex d enclosure that provides a suitable sealing surface for the connecting flange.

The service temperature range of the SR Ex e enclosures is up to -60°C to +120°C. The service temperature of the equipment depends on the type of gasket used.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	16 Oct 2020	R13108A/00	Issue of prime certificate

Note: Drawings that describe the equipment or component are listed in the Annex.

13 Conditions of Manufacture

None.

14 Schedule of Limitations

The following conditions relate to safe installation and/or use of the component.

- i. The SR range of enclosures have the following service temperature ranges. When assessed as part of equipment, these temperatures shall not be exceeded:
Where the BR099 gasket is used, Ts = -40°C to +120°C
Where the BR962 gasket is used, Ts = -40°C to +120°C
Where the EMI-01-255SAB is used, Ts = -60°C to +120°C
Where the EMI-401-255FR is used, Ts = -60°C to +120°C
Where the Fermasil gasket is used, Ts = -60°C to +120°C
- ii. The torque applied to the fasteners shall be at least 3 Nm.

Certificate Annex

Certificate Number CML 20ATEX3118U
Equipment SR Ex e Enclosures
Manufacturer Pepperl+Fuchs SE



The following documents describe the equipment or component defined in this certificate:

Issue 0

Drawing No.	Sheets	Rev.	Approved date	Title
16-1513CM-04	1 of 11	0	16 Oct 2020	SRM/L/X enclosure general assembly and sizes
16-1513CM-04	2 of 11	0	16 Oct 2020	SRS enclosure general assembly and sizes
16-1513CM-04	3 of 11	0	16 Oct 2020	SRS / SRM/L/X cover sealing arrangement
16-1513CM-04	4 of 11	0	16 Oct 2020	SRS / SRM/L/X cable entry and gland plate
16-1513CM-04	5 of 11	0	16 Oct 2020	SRS / SRM/L/X internal/external earth arrangement
16-1513CM-04	6 of 11	0	16 Oct 2020	SRM/L/X hinge arrangement
16-1513CM-04	7 of 11	0	16 Oct 2020	SRM/L/X enclosure fitted with double bit lock
16-1513CM-04	8 of 11	0	16 Oct 2020	SRM/L/X enclosure flanged to Ex d/e enclosure
16-1513CM-04	9 of 11	0	16 Oct 2020	Type A connecting Flange
16-1513CM-04	10 of 11	0	16 Oct 2020	Type B connecting Flange
16-1513CM-04	11 of 11	0	16 Oct 2020	Label/paint exceeding ESD limitations
16-1513CM-10	1 of 1	0	16 Oct 2020	SR* enclosure certification label