



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322303003533

APPLICANT: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim,Germany
MANUFACTURER: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim,Germany
FACTORY: Pepperl+Fuchs Asia Pte. Ltd.
ADDRESS: 18 Ayer Rajah Crescent, Singapore 139942

PRODUCT: Power Feed Module
SERIES,SPECIFICATION,MODEL: KFD2-EB2 Series
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.8-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:March 15, 2023

Valid until:December 17, 2025

Date of original certification:December 18, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:



 Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0006968



中国国家强制性产品认证证书



证书编号：2020322303003533

附 件

- 产品名称：** 配电模块
- 型号规格：** KFD2-EB2： 配电模块，螺钉接线端子
KFD2-EB2. SP： 配电模块，弹簧接线端子
KFD2-EB2. R4A. B： 冗余配电模块，螺钉接线端子
KFD2-EB2. R4A. B. SP： 冗余配电模块，弹簧接线端子
- 防爆标志：** Ex ec nC IIC T4 Gc
- 电气参数：** 额定电压：20~30Vd. c.
触点容量：30Va. c.， 2A； 40Vd. c.， 2A
- 相关报告编号：** 2022S17402-010236
- 使用条件：**
- 特殊（限制）使用条件：
 - 产品使用环境温度范围为-40℃~+70℃；
 - 当产品在应用于爆炸性气体危险场所 2 区时，应安装于满足 GB/T4208-2017 标准要求的 IP54 外壳防护等级，且符合 GB/T 3836.1 标准所规定的适当保护型式的外壳中；须保证仅可采用专用工具才能打开外壳；
 - 产品使用的区域污染等级不高于 GB/T16935.1-2008（IEC 60664-1）定义的 2 级。

批 准：



上海仪器仪表自控系统检验测试所有限公司