



中国国家强制性产品认证证书



证书编号: 2021322316004108

认证委托人名称: Pepperl+Fuchs SE
 认证委托人地址: Lilienthalstraße 200, 68307 Mannheim, Germany
 生产者名称: Pepperl+Fuchs SE
 生产者地址: Lilienthalstraße 200, 68307 Mannheim, Germany
 生产企业名称: Pepperl+Fuchs Asia Pte. Ltd.
 企业地址: 18 Ayer Rajah Crescent, Singapore 139942

产品名称: 隔离式安全栅
 系列、规格、型号: KFD2-PT2-Ex1ab
 标准: GB/T 3836.1-2021、GB/T 3836.4-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月22日

有效期至: 2026年06月24日

首次发证日期: 2021年06月25日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0009702



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322316004108

APPLICANT: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim, Germany
MANUFACTURER: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim, Germany
FACTORY: Pepperl+Fuchs Asia Pte. Ltd.
ADDRESS: 18 Ayer Rajah Crescent, Singapore 139942

PRODUCT: Isolated Barrier
SERIES,SPECIFICATION,MODEL: KFD2-PT2-Ex1ab
STANDARDS: GB/T 3836.1-2021、GB/T 3836.4-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:April 22, 2023

Valid until:June 24, 2026

Date of original certification:June 25, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0007692



中国国家强制性产品认证证书



证书编号: 2021322316004108

附件

产品名称: 隔离式安全栅

型号规格: KFD2-PT2-Ex1ab

a = 输出类型,

none = 0...10V 电压输出

-1 = 0...5V 电压输出

-4 = 0...20mA 电流输出

-5 = 4...20mA 电流输出

-6 = 0...24mA 电流输出

b = 选项, 与防爆性能无关(-Y98312 或者 -Y112844)

防爆标志: [Ex ia Ga] IIC

[Ex ia Da] IIIC

电气参数: KFD2-PT2-Ex1...

非本安端电气参数:

端子	电气参数
7, 8, 11&12, Power Rail	工作电压 (Un): 40Vd. c. 最高电压 (Um): 253Va. c.

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2021322316004108

附件

本安端：端子 1, 2, 3, 4&5 的电气参数：

最高输出电压 Uo (V)	最大输出电流 Io (mA)	最大输出功率 Po (mW)	最大等效内部参数	
			Ci (nF)	Li (mH)
10.4	31.4	82	0	0

气体组别	最大外部分布参数		
	Co (μF)	Lo (mH)	L/R (μH /ohm)
II C	2.52	36.07	170
II B/IIIC	17.40	132.57	652
II A	79.00	273.55	1203

KFD2-PT2-Ex1...Y...

非本安端电气参数：

端子	电气参数
7, 8, 11&12, Power Rail	工作电压 (Un): 40Vd. c. 最高电压 (Um): 253Va. c.

本安端：端子 1, 2, 3, 4&5 的电气参数：

最高输出电压 Uo (V)	最大输出电流 Io (mA)	最大输出功率 Po (mW)	最大等效内部参数	
			Ci (nF)	Li (mH)
10.4	46	120	0	0

批准：



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2021322316004108

附件

气体组别	最大外部分布参数		
	Co (μ F)	Lo (mH)	L/R (μ H /ohm)
II C	2.52	17.23	123
II B/III C	17.40	64.57	456
II A	79.00	136.24	901

相关报告编号： 2023S17402-011452

使用条件：
 1. 特殊（限制）使用条件：
 1) 产品使用环境温度范围为-20℃~+60℃

批 准：



上海仪器仪表自控系统检验测试所有限公司