



中国国家强制性产品认证证书



证书编号: 2021322310003756

认证委托人名称: Pepperl+Fuchs SE
认证委托人地址: Lilienthalstraße 200, 68307 Mannheim, Germany
生产者名称: Pepperl+Fuchs SE
生产者地址: Lilienthalstraße 200, 68307 Mannheim, Germany
生产企业名称: Pepperl+Fuchs Asia Pte. Ltd.
企业地址: 18 Ayer Rajah Crescent, Singapore 139942

产品名称: 网段保护器
系列、规格、型号: R-SP-E12
标准: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.9-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。
产品相关信息详见附件。

发证日期: 2023年03月22日

有效期至: 2026年02月22日

首次发证日期: 2021年02月23日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0008736



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322310003756

APPLICANT: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim, Germany
MANUFACTURER: Pepperl+Fuchs SE
ADDRESS: Lilienthalstraße 200, 68307 Mannheim, Germany
FACTORY: Pepperl+Fuchs Asia Pte. Ltd.
ADDRESS: 18 Ayer Rajah Crescent, Singapore 139942

PRODUCT: Segment Protector
SERIES, SPECIFICATION, MODEL: R-SP-E12
STANDARDS: GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.9-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Refer to the attachment for detailed information.

Valid from: March 22, 2023

Valid until: February 22, 2026

Date of original certification: February 23, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

s 0007034



中国国家强制性产品认证证书



证书编号: 2021322310003756

附 件

产品名称: 网段保护器

型号规格: R-SP-E12

防爆标志: Ex eb mb IIC T4 Gb

电气参数:

电路及端子	电气参数
电源 (主干): Trunk in, + & -	工作电源: 9~32V, ±10% 最大电流: 6A 预期短路电流: 100A
输出 (通路 1~12): + & -	每个通路最大值: 32V, 45mA

相关报告编号: 2023S17402-011204

使用条件:

- 特殊 (限制) 使用条件:
 - 产品使用环境温度范围为 -40°C~+70°C;
 - 产品应安装于满足 GB/T 3836.1 标准要求外壳中;
 - 产品只能使用认证的端子连接;
 - 产品附加的外壳只能在断电状态下打开;
 - 请遵守使用说明书中的安装说明。

批 准:



上海仪器仪表自控系统检验测试所有限公司