

Certificate



No.: 968/FSP 2300.00/21


Product tested	Isolated barriers, SMART Transmitter Power Supply	Certificate holder	Pepperl+Fuchs SE Lilienthalstraße 200 68307 Mannheim Germany
Type designation	HiD2030 HiD2030SK		
Codes and standards	IEC 61508 Parts 1-7:2010		
Intended application	The modules comply with the requirements of SIL 2 and SC 3 acc. to IEC 61508 and can be used in safety-related applications up to these levels.		
Specific requirements	The instructions of the associated Installation and Safety Manual shall be considered.		
Valid until	2026-08-09		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 2300.00/21 dated 2021-08-05.
This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2021-08-09

Certification Body Safety & Security for Automation & Grid


Dipl.-Ing. Gebhard Bouwer