



CML 21UKEX21403 UK Type Examination Certificate Issue

United Kingdom Conformity Assessment

1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) - Schedule 3A, Part 1

2 Equipment Isolated Switch Amplifier Type HiC2831* and type HiC2832*

3 Manufacturer PepperI+Fuchs SE

4 Address Lilienthalstrasse 200

68307 Mannheim

Germany

5 The equipment is specified in the description of this certificate and the documents to which it refers.

Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, 6 United Kingdom, Approved Body Number 2503, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

- If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section
- This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.
- Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-11:2012

The equipment shall be marked with the following:

) II (1) G

[Ex ia Ga] IIC

⟨£x⟩ _{II (1) D}

[Ex ia Da] IIIC

[Ex ia Ma] I

Certification Officer





11 Description

The Isolated Switch Amplifier type HiC2831* and type HiC2832* is an associated apparatus and transfers digital signals from the hazardous area to the safe area. The galvanic separation between the intrinsically safe circuits and the non-intrinsically safe circuits is done by transformers.

The Isolated Switch Amplifier has to be installed either outside hazardous areas or in a suitable enclosure; this assembly must be separately tested and certified.

1. Non-intrinsically safe circuits:

Power 9	Supply				
Connec	tor SL1: Pins 2a, 2b(+) - 1a, 1b (-)				
	ıl input voltage ım input voltage	U _n U _m	DC AC	1930 253	V V
Fault Si	ignal (fault bus)				
Connec	tor SL1: Pins 6b – 1a, 1b				
Maximu	ım input voltage	Um	AC	253	V
Galvani	ic isolated output 1				
Connec	tor SL1: Pins 7a - 8a				
Maximu	ım voltage	U_{m}	AC	253	V
Galvani	ic isolated output 2				
Connec	tor SL1: Pins 9a - 10a				

 U_{m}

AC

253

V

Intrinsically safe circuits:

Maximum voltage

Channel 1

Both intrinsically safe circuits are galvanically isolated from each other.

Uo Io Po	10.5 17.1 45	V mA mW
Ci Li	negligib negligib	
U _o I _o P _o	10.5 17.1 45	V mA mW
	Io Po Ci Li Uo Io	Io 17.1 Po 45 Ci negligib Li negligib Uo 10.5 Io 17.1

Maximum internal capacity

Maximum internal inductivity

Ci

Li

negligible

negligible





Nor the capacitance nor the inductance of the load connected to the output terminals must exceed the following values:

Group	IIC	IIB	IIA	I
Capacitance	2.41 µF	16.8 µF	75 µF	66 µF
Inductance	121.5 mH	486.3 mH	972.7 mH	1000 mH

The table is only applicable when the internal inductance Li or the internal capacitance Ci of the connected equipment is $\leq 1\%$ of the above specified tabular values.

If Li as well as Ci of the connected equipment are > 1% of the tabular values, all values specified in the table shall be reduced to 50%.

At this, the capacitance of the external circuit (capacitance of the cable + internal capacitance Ci of the connected equipment) shall not exceed $1\mu F$ for I, IIA, IIB and 600nF for IIC

Ambient temperature range

Ta

-40°C to +70°C.

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	17 Feb 2022	R14112CE/00	Prime Certificate issued.

Note: Drawings that describe the equipment are listed or referred to in the Annex.

13 Conditions of Manufacture

None.

14 Specific Conditions of Use

None.

Certificate Annex

Certificate Number CML 21UKEX21403

Equipment Isolated Switch Amplifier Type HiC2831* and type

HiC2832*

Manufacturer Pepperl+Fuchs SE

The following documents describe the equipment defined in this certificate:

Issue 0

For drawings describing the equipment, refer to attached certificate BVS 11 ATEX E 026 Issue 1. In addition to the drawings listed on BVS 11 ATEX E 026 Issue 1, the following drawings include the additional marking required for this UK Type Examination certification:

Drawing No	Sheets	Rev	Approved date	Title
16-1555CM-10	1 to 2	0	17 Feb 2022	Additional Marking Requirements for UKCA

