



# Mining And Surface Certification (Pty) Ltd

2015/021934/07

THIS CERTIFICATE IS ISSUED AS AN I.A. CERTIFICATE IN TERMS OF THE MINE HEALTH AND SAFETY ACT, ACT NO 29 OF 1996 (AND REGULATIONS), THE OCCUPATIONAL HEALTH AND SAFETY ACT (ACT 85 OF 1993) AND REGULATION 17 OF THE ELECTRICAL MACHINERY REGULATIONS

IA CERTIFICATE	MASC MS/18-0089	X	Issue	1					
Issue Date	23 May 2022		Expiry Date	23 July 2024					
** Based on Certificate No	IECEx CES 06.000	2X	Issue / Variation	ns / Amendment 3					
Requested by	Pepperl+Fuchs (Pty	Pepperl+Fuchs (Pty) Ltd							
	8 Glen Eagle Office	Park, Koorsl	ooom Ave, Glen N	Marais, Kempton Park, 16	19 , South Africa				
Manufacturer	Pepperl+Fuchs SE								
		strasse 200, 68307 Mannheim, Germany							
Description	The SMART Transmitter Power Supply HiC2025 and HiC2025A and SMART Current Driver HiC2031 are galvanically isolated apparatus. The equipment's input circuit is isolated from the output circuit by transformer. The voltage and current limitation for the input circuit is achieved with zener diodes and current limiting resistors. All the devices are mounted inside a plastic housing and equipped with two multipolar connectors type DIN 41612 B/3, suitable for direct insertion into Pepperl+Fuchs's certified Termination Boards, HiC series. The product names shall be supplemented by additional characters, indicating equipment variants that have no influence on the approval.  Both products do not differ from those for Intrinsic Safety applications.  See annex of Base certificate for further description								
Equipment	Galvanically Isolate	ed Barrier	Type HiC2	025, HiC2025A and HiC2	031				
MARKING:	Type:	Galvanically	y Isolated Barrier,	type HiC2025, HiC2025A	and HiC2031				
Original marking as per	Ex Marking:	[Ex ia Ma] I							
certificate ** remains		[Ex ia Ga] II	C						
applicable.		[Ex ia Da] II							
IA number must be added.		Ex ec IIC T4							
	IA Number:			additionally marked on ed					
	Warnings: See Base Certificate ** (original marking must be applied)								
Quality Assurance report (QA (QAN):	AR) / Notification	DE/PTB/QA	AR06.0008/17	7///					
Quality Assurance report (QA (QAN) Expiry date:	AR) / Notification	23 July 2024							
Compliance									

#### Compliance:

The equipment as described above has been allocated the rating Explosion Protected 'as above' utilizing the SANS/IEC Standards:

• SANS (IEC) 60079-0: 2017 Equipment - General requirements

SANS (IEC) 60079-7:
 SANS (IEC) 60079-11:
 2011 Equipment protection by intrinsic safety "i" Equipment protection by increased safety "e"

Note: This certificate covers only the listed standards and does not imply compliance to any other standard, related or inferred. It is up to the manufacturer to ensure that the product complies to all relevant standards for the application.

#### Special conditions of safe use "X":

Refer to Annex A below for more details

#### Conditions of manufacture:

· Refer to Annex A below for more details.

D.P Visser
TECHNICAL SPECIALIST

N. Viljoen TECHNICAL OFFICER

This certificate covers all units sold as long as the QAR/QAN remains valid.

According to the relevant requirements of the MHS Act and the OHS Act, production units of explosion protected equipment are required to comply with third party quality assurance (an approved mark scheme or batch testing by an accredited test laboratory).

Apparatus in hazardous locations is subject to the following provisions as applicable, which shall be adhered to:

SANS 10086 requirements;

Any conditions mentioned in the above certificate; Any relevant requirements of the MHS Act

Any restrictions and conditions enforced by the chief inspector of mines, principal inspector (Group I equipment) or chief inspector of factories (Group II equipment).

This certificate may only be reproduced in full

The certificate is not transferable and remains the property of the issuing body.

#### IA CERTIFICATE: MASC MS/18-0089X

# Equipment: Galvanically Isolated Barrier, HiC2025, HiC2025A and HiC2031 (Expiry date: 23 July 2024)

Page 2 of 2

#### **ANNEX A**

This	document is based on and must be read in conjunction with certificate IECEx CES 06.0002X.								
	Description (According to Base Certificate) **								
"Refer to description in	n Base Certificate ** (and any applicable schedules/issues/variations)."								
Standard compliance	See Base Certificate **								
Special conditions of safe use ("X")	<ul> <li>Products shall only be used, with the designated Pepperl+Fuchs HiC seires, Termination Boards         Installation in areas that requiring EPL Gc equipment     </li> <li>The equipment shall be installed in a suitably certified enclosure such that it is afforded a degree of protection of at least IP54 in accordance with IEC 60079-0, IEC 60079-7 &amp; IEC 60529 and it shall be located and operated in a controlled environment that ensures a pollution degree 2, as defined in IEC 60664-1.</li> <li>The device must be installed and operated only in an environment of overvoltage category II (or better) according to IEC/EN 60664-1.</li> <li>Connection or disconnection of energized non-intrinsically safe circuits is only permitted in the absence</li> </ul>								
Conditions of manufacture	of a potentially explosive atmosphere.  None.								
Conditions of Certification	<ul> <li>This IA Certificate covers all units sold from the date of this document to the expiry date of this certificate.</li> <li>As per ARP 0108 a maximum three yearly review is required on this IA Certificate (expiry is determined as per the QAR/QAN/QMS expiry date).</li> <li>The apparatus must be additionally marked with the MASC marking details above.</li> <li>This approval only covers the equipment as certified above and does not include any scheduled additions or variations / amendments / new issues to the certificate(s), made after the above date.</li> <li>The equipment does not need to be re-tested when used on the conditions and with such restrictions as prescribed by the certificate on which this IA Certificate is based and any other conditions in this IA Certificate.</li> <li>The certification on which this IA Certificate is based must remain valid.</li> <li>The extent of the requirements in the ARP 0108 (or regulations), SANS 10108 and any other applicable regulations on the certification of the equipment must remain unchanged.</li> <li>The Ex quality assurance notification/report for the equipment must remain valid.</li> </ul>								
Conclusion:	<ul> <li>From the above and the selective examination of the documentation, nothing contrary to the requirements of the applicable standards was found, provided that the equipment / component is used as described in the above document / certificate and according to the MASC conditions below. A MASC IA certificate is issued based on the work done as per the Base Certificate **.</li> <li>The routine tests for production units according to the Base Certificate ** must be complied with (if applicable).</li> </ul>								

This document is issued based on Mining And Surface Certification's Standard Contract terms and conditions available on request.

While every endeavour is made to ensure that a test / assessment / inspection is representative and accurately performed, and that a report / certificate is accurate in the quoted results and conclusions drawn from the test / assessment / inspection, MASC or its directors/employees shall in no way be liable for any error made in carrying out the test / assessment or for any erroneous statement, whether in fact or in opinion, contained in a report / certificate issued pursuant to a test / assessment / inspection.

MASC takes no responsibility for any non-conformances, exclusions or any results / assessments / inspections not in compliance with the standards. By marking the equipment in accordance with the documentation / standard, the manufacturer / applicant attests on his own responsibility that the equipment / installation has been designed and constructed in accordance with the applicable requirements of the relevant standards and documentation, that the routine verifications / routine tests have been correctly completed and the equipment / installation complies with the documentation and standard(s).

This document is only for use and application in South Africa. It is issued based on National interpretations and accepted practices.

This document may only be reproduced in full.

This certificate is not transferable and remains the property of the issuing body.

This document will not be supported by MASC for certification purposes outside the borders of South Africa.



### INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification System for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx CES 06.0002X** Page 1 of 4

Current Issue No: 3 Status:

Date of Issue: 2021-05-24

PepperI+Fuchs SE Applicant:

> Lilienthalstrasse 200 68307 Mannheim

Germany

Equipment: Galvanically Isolated Barrier, type HiC2025, HiC2025A and HiC2031

Optional accessory:

Type of Protection: Intrinsic safety 'ia'; Increased safety 'ec'

Marking: [Ex ia Ma] I

> [Ex ia Ga] IIC [Ex ia Da] IIIC Ex ec IIC T4 Gc

Approved for issue on behalf of the IECEx Mirko Balaz

Certification Body:

Position: **Head of IECEx CB** 

Signature:

(for printed version)

(for printed version)

- This certificate and schedule may only be reproduced in full.
   This certificate is not transferable and remains the property of the issuing body.
   The Status and authenticity of this certificate may be verified by visiting <a href="https://www.iecex.com">www.iecex.com</a> or use of this QR Code.



Certificate history: Issue 2 (2019-07-15)

Issue 1 (2011-08-29) Issue 0 (2006-07-05)

Certificate issued by:

**Centro Elettrotecnico** Sperimentale Italiano S.p.A. Via Rubattino 54 20134 Milano Italy





Certificate No.: IECEx CES 06.0002X Page 2 of 4

Date of issue: 2021-05-24 Issue No: 3

Manufacturer: Pepperl+Fuchs SE

Lilienthalstrasse 200 68307 Mannheim **Germany** 

Additional Pepperl+Fuchs Asia Pte. Ltd.

manufacturing 18 Ayer Rajah Crescent locations: Singapore 139942

**Singapore** 

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

#### STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements

Edition:7.0

1 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

IEC 60079-11:2011 Edition:6.0

IEC 60079-7:2015 Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

Edition:5.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### **TEST & ASSESSMENT REPORTS:**

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

Quality Assessment Report:

IT/CES/ExTR21.0005/00

DE/PTB/QAR06.0008/15



Certificate No.: IECEx CES 06.0002X Page 3 of 4

Date of issue: 2021-05-24 Issue No: 3

#### **EQUIPMENT:**

Equipment and systems covered by this Certificate are as follows:

The SMART Transmitter Power Supply HiC2025 and HiC2025A and SMART Current Driver HiC2031 are galvanically isolated apparatus.

For intrinsic safety applications they are associated apparatus.

The devices HiC2025 and HiC2025A supplies 2-wire SMART transmitters in a hazardous area and can also be used with 2-wire SMART current sources. It transfers the analog input signal to the safe area as an isolated current value.

The SMART Current Driver type HiC2031 repeats the input signal from a control system to drive HART I/P converters, valve actuators, and displays located in a hazardous area.

For non incendive applications (type of protection Ex ec).

The devices HiC2025 and HiC2025A are isolated apparatus suitable to supply/interface signal transmitter placed in hazardous area and transfer the analog signal to a safe area.

The device HiC2031 is an isolated apparatus suitable to repeat a current signal coming from a safe area to drive smart I/P converter, valve actuator and displays placed in hazardous area.

Both products do not differ from those for Intrinsic Safety applications.

See annex for further description.

#### SPECIFIC CONDITIONS OF USE: YES as shown below:

- Products shall only be used, with the designated Pepperl+Fuchs HiC seires, Termination Boards.

Installation in areas that requiring EPL Gc equipment

- The equipment shall be installed in a suitably certified enclosure such that it is afforded a degree of protection of at least IP54 in accordance with IEC 60079-0, IEC 60079-7 & IEC 60529 and it shall be located and operated in an controlled environment that ensures a pollution degree 2, as defined in IEC 60664-1.
- The device must be installed and operated only in an environment of overvoltage category II (or better) according to IEC/EN 60664-1.
- Connection or disconnection of energized non-intrinsically safe circuits is only permitted in the absence of a potentially explosive atmosphere.



Certificate No.: IECEx CES 06.0002X Page 4 of 4

Date of issue: 2021-05-24 Issue No: 3

## DETAILS OF CERTIFICATE CHANGES (for issues 1 and above) Details of certificate changes (for issues 2):

#### Variation 2.1

The constructive modifications introduced by the Manufacturer, relate to the improvement the thermal dissipation of the infallible components on which intrinsic safety depends in relation to the maximum service temperature of +94 °C.

#### Variation 2.2

Extended the ambient temperature range from -20 °C ÷ +60°C up to -40 °C ÷ +70 °C.

#### Variation 2 3

New alternative I.S. components and PCBs modification.

#### Variation 2.4

Added new type of protection "ec", for EPL Gc (IEC 60079-7:2015).

#### Variation 2.5

Added electrical data for EPL Gc. Electrical data for "i" remains unchanged.

#### Variation 2.6

Added a new device called HiC2025A with new external safety parameters.

#### Variation 2.7

The product denomination has been updated, introducing asterisks at the end of name. The asterisks shown in at the end of the name can be replaced by a combination of tokens, indicating different versions that have no influence on the approval (e.g. HiC2025(A)\*\* or HiC2031\*\*). The external safety parameters are the same as for the standard version and have not any influence on the type of protection.

#### Variation 2.8

The Manufactory location(s) have been update.

#### Variation 2.9

The equipment have been assessed in compliance to IEC 60079-0:2007, IEC 60079-11:2006, IEC 60079-26:2006, IEC 61241-11:2005. The equipment have been re-assessed on the basis of IEC 60079-0:2017 and IEC 60079-11:2011 Standards.

#### Variation 2.10

Update "Specific Conditions of Use" / "Schedule of Limitations"

#### Variation 3 (Issue No.3):

#### Variation 3.1

Updated the Applicant and Manufacturer name.

#### Variation 3.2

Updated the Additional Manufacturing locations.

No other changes were applied to the Equipment.

#### Annex:

P+F IECEx\_CES\_06.0002X Issue 3 - ANNEX - HiC2025+HiC2031.pdf





Annex to certificate:

IECEx CES 06.0002X Issue No.:3 of 2021-05-24

Applicant:

Pepperl+Fuchs SE

Lilienthalstrasse 200; 68307 Mannheim - Germany

Galvanically isolated barrier type: HiC2025, HiC2025A and HiC2031 **Electrical Apparatus:** 

#### **Description of product**

The SMART Transmitter Power Supply HiC2025 and HiC2025A and SMART Current Driver HiC2031 are galvanically isolated apparatus.

The equipment's input circuit is isolated from the output circuit by transformer. The voltage and current limitation for the input circuit is achieved with zener diodes and current limiting resistors.

All the devices are mounted inside a plastic housing and equipped with two multipolar connectors type DIN 41612 B/3, suitable for direct insertion into Pepperl+Fuchs's certified Termination Boards, HiC series.

The product names shall be supplemented by additional characters, indicating equipment variants that have no influence on the approval.

#### For intrinsic safety applications they are associated apparatus.

The devices HiC2025 and HiC2025A supplies 2-wire SMART transmitters in a hazardous area and can also be used with 2-wire SMART current sources. It transfers the analog input signal to the safe area as an isolated current value. Digital signals may be superimposed on the input signal in the hazardous or safe area and are transferred bi-directionally. Selectable output of current source, sink mode, or voltage output is available via DIP switches. The product supports the following SMART protocols: HART or BRAIN.

The device HiC2031 drives SMART I/P converters, electrical valves, and positioners in hazardous areas. Digital signals are superimposed on the analog values at the field or control side and are transferred bidirectionally. Current transferred across the DC/DC converter is repeated at terminals 1 and 2. Sockets for the connection of a HART communicator are integrated into the terminals of the device.

#### For non incendive applications (type of protection Ex ec).

The devices HiC2025 and HiC2025A are isolated apparatus suitable to supply/interface signal transmitter placed in hazardous area and transfer the analog signal to a safe area. The safe area connections are the Power Supply and Output. The Hazardous Area connections (Input circuit) are for Sink Input (2-wire transmitters) or Source Input (4-wire transmitters). A digital smart communication may be superimposed on the transmitter measure signal as input or output and may be transferred in both directions.

The device HiC2031 is an isolated apparatus suitable to repeat a current signal coming from a safe area to drive smart I/P converter, valve actuator and displays placed in hazardous area. A digital smart communication may be superimposed on the transmitter measure signal as input or output and may be transferred in both directions.

The products do not differ from that for Intrinsic Safety applications.

#### Electrical characteristic-type of protection: [Ex ia]

Non-intrinsically safe circuits

Power supply - Connector SL1 pins: 2a,2b (+) and 1a,1b (-)

Um: 250 Vac Rated voltage Un: 24 Vdc (19 ÷ 30 Vdc)

Analog Input/Output - Connector SL1 pins: 8a (+) and 7a (-)

Um: 250 Vac Rated voltage Un: up to 30 Vdc

Tamb.: -40°C up to +70 °C

#### Intrinsically safe circuits - equipment HiC2025\*\*

	numsically safe circuits — equipment Inczozs									
Connecto	Connector SL2	Uo	la la	Ро	Gas	Co	Lo	Lo/Ro		
	pins	0	lo		Group	(µF)	(mH)	$(\mu H/\Omega)$		
5a(+); 5b(-)					IIC	0.100	3.5	55		
	25.2V	100 mA	630 mW	IIB	0.81	14	222			
				IIA	2.8	28	444			
					1	4.14	46	743		

Ci = 5.7nF;

Li = negligible;

Output characteristic: linear.





Annex to certificate:

IECEx CES 06.0002X Issue No.:3 of 2021-05-24

**Applicant:** 

Pepperl+Fuchs SE

Lilienthalstrasse 200; 68307 Mannheim - Germany

Galvanically isolated barrier type: HiC2025, HiC2025A and HiC2031 **Electrical Apparatus:** 

#### Intrinsically safe circuits - equipment HiC2025\*\*

Connector SL2	Uo	lo	Po	Gas	Co	Lo	Lo/Ro
pins	Ui	li		Group	(µF)	(mH)	(μΗ/Ω)
5a(+); 1b(-) 7a(-)	7.2V #	100 mA	25 mW	IIC	13.49	3.5	27
				IIB	239	14	108
	00.17	400 4		IIA	1000	28	216
	30 V 128 mA		I	1000	46	356	

Ci = 5.7nF;

Li = negligible;

Output characteristic: diodes blocking barrier.

#### Intrinsically safe circuits - equipment HiC2025A\*\*

Connector SL2	1 110	lo	Ро	Gas	Co	Lo	Lo/Ro
pins				Group	(µF)	(mH)	(μΗ/Ω)
5a(+); 5b(-)	25.2V	93 mA	586 mW	IIC	0.100	4.1	61
				IIB	0.81	16.4	244
				IIA	2.8	32.8	488
				I	4.14	53.9	800

Ci = 5.7nF;

Li = negligible;

Output characteristic: linear.

Connector SL2	Uo	lo	Po	Gas	Co	Lo	Lo/Ro
pins	Ui	li		Group	(µF)	(mH)	(mH/Ω)
5a(+); 1b(-) 7a(-)	1	100 mA		IIC	100	3.5	1.4
			25 mW	IIB	1000	14	5.6
	001/	√ 128 mA		IIA	1000	28	11.2
	30 V			I	1000	46	18

Ci = 5.7nF;

Li = negligible;

Output characteristic: diodes blocking barrier.

#### Intrinsically safe circuits - equipment HiC2031\*\*

Connector SL2	Connector SL2 Uo	lo	Ро	Gas	Co	Lo	Lo/Ro
pins				Group	(µF)	(mH)	(μΗ/Ω)
5a(+); 5b(-)	25.2V	100 mA	630 mW	IIC	0.100	3.5	55
				IIB	0.81	14	222
				IIA	2.8	28	444
				I	4.14	46	743

Ci = 5.7nF;

Li = negligible;

Output characteristic: linear.

#### Note - External circuits with both inductance and capacitance

The above maximum Lo and Co parameters apply where:

- the total Ci of the external circuit (excluding the cable) is < 1% of the Co value
- the total Li of the external circuit (excluding the cable) is < 1% of the Lo value.

The above Lo and Co parameters shall reduce to 50% when both of the two conditions below are given:

- the total Li of the external circuit (excluding the cable) > 1% of the Lo value
- the total Ci of the external circuit (excluding the cable) > 1% of the Co value.

The reduced capacitance of the external circuit (including cable) shall not be greater than 1 uF for Groups I, IIA, IIB and 600 nF for Group IIC.

<sup>#</sup> The voltage Uo, of channel 5a(+); 1b(-) 7a(-) is derived from the Ui voltage max 30 V





Annex to certificate:

Applicant:

IECEx CES 06.0002X Issue No.:3 of 2021-05-24

Pepperl+Fuchs SE

Lilienthalstrasse 200; 68307 Mannheim - Germany

**Electrical Apparatus:** Galvanically isolated barrier type: HiC2025, HiC2025A and HiC2031

Dust protection [ia Da] IIIC: the barriers HiC2025, HiC2025A and HiC2031 meet the spark ignition energy level requirements for Groups IIB apparatus.

#### Electrical characteristic - type of protection: Ex ec

Power Supply [Connector SL1 pins: 2a(+), 2b(+); 1a(-), 2b(-)]. rated voltage Un: 24 Vdc (from 19 V up to 30 V)

Devices HiC2025\*\* and HiC2025A\*\*

Input [Connector SL2 pins: 5a(+); 5b(-)]. 0/4 ÷ 20 mA signal (Un >15 V at 20 mA) Input [Connector SL2 pins: 5a(+); 1b(-), 7a(-)]. 0/4 ÷ 20 mA signal (up to Un: 30 V max) Output [Connector SL1 pins: 8a(+); 7a(-)]: 0/4 ÷ 20 mA signal (up to Un: 30 V max)

#### Device HiC2031\*\*

Input [Connector SL1 pins: 8a(+); 7a(-)]. 0/4 ÷ 20 mA signal (up to Un: 30 V max) Output [Connector SL2 pins: 5a(+); 5b(-)].  $0/4 \div 20 \text{ mA signal } (0 \div 650 \Omega \text{ loadx})$ 

from -40 °C up to +70 °C Tamb.:

The maximum electrical values, at input/output terminals, are those above defined for the [Ex ia] type of protection.