



## EU-TYPE EXAMINATION CERTIFICATE

Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

Certificate Number: **CSANe 22ATEX1074X** Issue: **1**

Equipment: **VIM6\*\*\*\_\*\*V\*\*\_\*\*N\*, VIM6\*\*\*\_\*\*T\*\*\_\*\*N\*,  
VIM6\*\*\*\_\*\*G\*\*\_\*\*N\*, VIM6\*\*\*\_\*\*F\*\*\_\*\*N\*,  
VIM6\*\*\*\_\*\*V\*\*\_\*\*P\***

Applicant: **Pepperl+Fuchs SE**

Address: Lilienthalstrasse 200  
Mannheim, Baden-Württemberg  
68307  
Germany

This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN IEC 60079-0:2018/AC:2020-02 EN 60079-1:2014 IEC 60079-11:2023 Ed 7 EN 60079-31:2014

If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.

This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.

The marking of the equipment shall include the following:

**VIM6\*\*\*\_\*\*V\*\*\_\*\*N\*, VIM6\*\*\*\_\*\*T\*\*\_\*\*N\*,  
VIM6\*\*\*\_\*\*G\*\*\_\*\*N\*, VIM6\*\*\*\_\*\*F\*\*\_\*\*N\***



II 2GD  
Ex db IIC T4 Gb  
Ex tb IIIC T120°C  
Ta = -40°C to +60°C

**VIM6\*\*\*\_\*\*V\*\*\_\*\*P\***



II 2GD  
Ex ib IIC T4 Gb  
Ex ib IIIC T125°C Db  
Ta = -40°C to +60°C

Signed: M Halliwell

Title: Senior Director of Operations



Project Number 80249361

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

CSANe22ATEX1074X

Issue 1

#### 13 DESCRIPTION OF EQUIPMENT

##### **VIM6\*\*\*\_\*\*V\*\*\_N\* and VIM6\*\*\*\_\*\*V\*\*\_P\***

The vibration control is used for measurement and monitoring the absolute bearing vibration at machines according to the standard DIN ISO 10816.

The VIM6\*\*\*\_\*\*V\*\*\_N\* is equipped with an integrated cable and is as Ex d / Ex tb-Version variable. The VIM6\*\*\*\_\*\*V\*\*\_P\* is the Ex ib Version and is equipped with an M12 plug connection. Only Pin 1 and 3 is used the plug connection.

The VIM6\*\*\*\_\*\*V\*\*\_P\* is the Ex ib Version and is equipped as Standard with an M12 Plug connection and alternatively with an integrated cable, the same design as by the VIM6\*\*\*\_\*\*V\*\*\_N\*.

##### **VIM6\*\*\*\_\*\*T\*\*\_N\***

The vibration control is used for measurement and monitoring the absolute bearing vibration at machines according to the standard DIN ISO 10816. Furthermore this vibration control is equipped with a temperature sensor for measuring the surface temperature of the machine. The VIM6\*\*\*\_\*\*T\*\*\_N\* is only as Ex d / Ex tb-Version available.

##### **VIM6\*\*\*\_\*\*G\*\*\_N\***

The vibration monitoring type VIM6\*\*\*\_\*\*G\*\*\_N\* is used for measuring and monitoring of Vibrations used on machines.

It has the following features:

- Operating principle: the two-wire system.
- Measured variable: The effective value (rms) of the vibration acceleration in g.
- Analog current output: Interference-proof direct current signal of 4 ... 20 mA, proportional to the measuring range of the monitoring.
- Cable break on the monitoring cable can be detected by a following signal conditioning instrument:

Value of the DC signal <3.5 mA.

##### **VIM6\*\*\*\_\*\*F\*\*\_N\***

The vibration monitoring type VIM6\*\*\*\_\*\*F\*\*\_N\* is used to measure and monitor the absolute Bearing vibration on machines used in accordance with the standard DIN ISO 10816.

It has the following features:

- Operating principle: the two-wire system.
- Measured variable: The effective value (rms) of the vibration velocity in mm / s.
- The RMS averaging time is 60 s.
- Analog current output: Interference-proof direct current signal of 4 ... 20 mA, proportional to the measuring range of the monitoring.
- Cable break on the monitoring cable can be detected by a following signal conditioning instrument:

Value of the DC signal <3.5 mA.

Project Number 80249361

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

CSANe22ATEX1074X

Issue 1

#### Electrical Data

|                                                                                                                                  |    |               |
|----------------------------------------------------------------------------------------------------------------------------------|----|---------------|
| <b>VIM6***_**V**_**N*</b>                                                                                                        |    |               |
| Max. input voltage vibration control:                                                                                            | Un | 10 V to 30 V  |
| Max. input current vibration control:                                                                                            | In | 4 mA to 25 mA |
| <b>VIM6***_**V**_**P*</b>                                                                                                        |    |               |
| Power supply and signal circuit                                                                                                  |    |               |
| At the ignition protection level intrinsic safety Ex ib IIC or IIIC only for connection with a certified intrinsic safe circuit. |    |               |
| Maximum values:                                                                                                                  |    |               |
| Max. input voltage vibration control:                                                                                            | Ui | 30 V DC       |
| Max. input current vibration control:                                                                                            | Ii | 100 mA DC     |
| Max. input power vibration control:                                                                                              | Pi | 800 mW        |
| Input capacitance vibration control:                                                                                             | Ci | 44 nF         |
| Input inductance vibration control:                                                                                              | Li | 0 µH          |
| <b>VIM6***_**T**_**N*</b>                                                                                                        |    |               |
| Max. input voltage vibration control:                                                                                            | Un | 10 V to 30 V  |
| Max. input current vibration control:                                                                                            | In | 8 mA to 50 mA |
| <b>VIM6***_**G**_**N*</b>                                                                                                        |    |               |
| Max. input voltage vibration control:                                                                                            | Un | 10 V to 30 V  |
| Max. input current vibration control:                                                                                            | In | 4 mA to 25 mA |
| <b>VIM6***_**F**_**N*</b>                                                                                                        |    |               |
| Max. input voltage vibration control:                                                                                            | Un | 10 V to 30 V  |
| Max. input current vibration control:                                                                                            | In | 4 mA to 25 mA |

**Variation 1** - This variation introduced the following changes:

- Update of entity parameters (Pi) parameters for the intrinsically safe variant (VIM6\*\*\*\_\*\*V\*\*\_\*\*P\*).
- Update of instruction manuals.
- Following appropriate assessment to demonstrate compliance with the latest technical knowledge EN 60079-11:2012 was replaced by IEC 60079-11 Ed.7 (2023).

## 14 DESCRIPTIVE DOCUMENTS

### 14.1 Drawings

Refer to Certificate Annexe.

### 14.2 Associated Reports and Certificate History

| Issue | Date           | Report number | Comment                               |
|-------|----------------|---------------|---------------------------------------|
| 0     | 08 August 2022 | R80130975A    | The release of the prime certificate. |
| 1     | 03 June 2025   | R80249360A    | The introduction of Variation 1.      |

Project Number 80249361

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands



## SCHEDULE

### EU-TYPE EXAMINATION CERTIFICATE

**CSANe22ATEX1074X**  
**Issue 1**

- 15 **SPECIFIC CONDITIONS OF USE** (denoted by X after the certificate number)
- 15.1 The ambient temperature range is between -40°C and +60°C.
- 15.2 The vibration monitoring VIM6\*\*\*\_\*\*V\*\*\_P\* may only be operated in a certified intrinsically safe circuit according to Ex ib IIC / Ex ib IIIC.
- 15.3 Integration into the potential equalization is carried out via the installation.
- 15.4 The operating instructions must be observed.
- 15.5 The electronic data can be found in the EU-type examination certificate.
- 16 **ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II** (EHSRs)
- The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.
- 17 **CONDITIONS OF MANUFACTURE**
- 17.1 The use of this certificate is subject to the Regulations Applicable to Holders of CSA Group Netherlands B.V. certificates.
- 17.2 Holders of EU-Type Examination Certificates are required to comply with the conformity to type requirements defined in Article 13 of Directive 2014/34/EU.

# Certificate Annexe



**Certificate Number:** CSANe 22ATEX1074X

**Equipment:** VIM6\*\*\*\_\*\*V\*\*\_\*N\*, VIM6\*\*\*\_\*\*T\*\*\_\*N\*  
VIM6\*\*\*\_\*\*G\*\*\_\*N\*, VIM6\*\*\*\_\*\*F\*\*\_\*N\*  
VIM6\*\*\*\_\*\*V\*\*\_\*P\*

**Applicant:** Pepperl+Fuchs SE

## Issue 0

| Drawing      | Sheets | Rev. | Date (Stamp) | Title         |
|--------------|--------|------|--------------|---------------|
| 16-1596CS-10 | 1 to 3 | -    | 13 Jul 22    | Label Drawing |

**Issue 1** – No new drawings were introduced.

Project Number 80249361

This certificate and its schedules may only be reproduced in its entirety and without change  
CSA Group Netherlands B.V. Utrechtseweg 310, Building B42, 6812AR Arnhem, The Netherlands