

Certificate of Compliance

Certificate Number:

E223772

Report Reference:

E223772-20230807

Issue Date:

2026-MAY-20

Issued to:

Pepperl+Fuchs SE
Lilienthalstrasse 200 Mannheim 68307 Germany

This certificate confirms that representative samples of:

PROGRAMMABLE CONTROLLERS (NRAQ, NRAQ7)

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CAN/CSA-C22.2 No. 61010-1-12, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
UL 61010-1, Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements.

UL 61010-2-201 & CSA C22.2 No. 61010-2-201:18, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 2-201: Particular Requirements for Control Equipment.

Additional Information:

See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): E223772
Report reference: E223772-20230807
Issue Date: 2026-MAY-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Products Covered	Product Designation	Nomenclature
Unmanaged Industrial Ethernet Switch	ICRL2-U-16RJ45-G-DIN	
Unmanaged Industrial Ethernet Switch	ICRL2-U-5RJ45-5V-DIN-I	
Programmable Controllers	ICRL2-M-16RJ45.4SFP-10G-DIN	
Unmanaged Industrial Ethernet Switch	ICRL2-U-8RJ45-DIN	
Unmanaged Industrial Ethernet Switch	ICRL2-U-5RJ45-DIN	
Unmanaged Industrial Ethernet Switch	ICRL2-U-8RJ45-G-DIN	
Unmanaged Industrial Ethernet Switch	ICRL2-U-5RJ45-G-DIN	