CERTIFICATE OF COMPLIANCE

Certificate Number	E106378
Report Reference	E106378-2019-09-03
Date	2023-March-31
Issued to:	Pepperl+Fuchs SE Lilienthalstrasse 200 Mannheim 68307 DE
This is to certify that representative samples of	PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS - COMPONENT See Addendum Page for Product Designation(s).
	Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.
Standard(s) for Safety:	See Addendum Page for Standard(s).
Additional Information:	See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	E106378
Report Reference	E106378-2019-09-03
Date	2023-March-31

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Product Designation(s):

Associated Apparatus for use in Unclassified Locations or Class I, Division 2, Groups A, B, C, and D and Class I, Zone 2, AEx ec [ia Ga] IIC, and Ex ec [ia Ga] IIC Hazardous Locations.

Models HiC2025, may be followed by additional alphanumeric characters, followed by P/N 321423; HiC2025A , may be followed by additional alphanumeric characters, followed by P/N 321425; and HiC2031, may be followed by additional alphanumeric characters; providing intrinsically safe circuits for use in hazardous locations,

- Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III; or
- Class I, Zone 0, Group IIC;

when installed in accordance with manufacturer's Control Drawing No. 116-0458A.

Models HiC2025, may be followed by additional alphanumeric characters, followed by P/N, followed by 8 numeric characters; HiC2025A, may be followed by additional alphanumeric characters, followed by P/N, followed by 8 numeric characters; and HiC2031, may be followed by additional alphanumeric characters; providing intrinsically safe circuits for use hazardous locations,

- Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III; or
- Class I, Zone 0, Group IIC;

when installed in accordance with manufacturer's Control Drawing No. 116-0458B.

Standard(s) for Safety:

UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations,

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,

UL 60079-0, Explosive Atmospheres - Part 0: Equipment - General Requirements,

UL 60079-7, Explosive atmospheres - Part 7: Equipment protection by increased safety "e",

UL 60079-11, EXPLOSIVE ATMOSPHERES - PART 11: EQUIPMENT PROTECTION BY INTRINSIC SAFETY 'I',

UL 61010-1, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements,

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	E106378
Report Reference	E106378-2019-09-03
Date	2023-March-31

CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,

CSA C22.2 No. 157, Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations,

CSA C22.2 No. 60079-0, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements,

CSA C22.2 No. 60079-7, Explosive Atmospheres - Part 7: Equipment Protection by Increased Safety "e",

CSA C22.2 No. 60079-11, Explosive Atmospheres - Part 11: Equipment Protection by Intrinsic Safety "i",

CSA C22.2 No. 61010-1-12, Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/