


UK Type Examination Certificate CML 23UKEX2154 Issue 0**United Kingdom Conformity Assessment**


- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **Safety isolation amplifier type KFD2-SH-Ex1.T*****
- 3 Manufacturer **Pepperl+Fuchs SE**
- 4 Address **Lilienthalstrasse 200
68307 Mannheim
Germany**
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018 EN 60079-11:2012

10 The equipment shall be marked with the following:

 II (1) G
[Ex ia Ga] IIC

 II (1) D
[Ex ia Da] IIIC



CML 23UKEX2154
Issue 0

11 Description

The safety isolation amplifier type KFD2-SH-Ex1.T*** is used for the transmission of control commands from the explosion hazardous area into the non-explosion hazardous area.

The safety isolation amplifier type KFD2-SH-Ex1.T*** must be installed outside of the explosion hazardous area.

The maximum permissible ambient temperature range is unchanged from -20 °C to 60°C.

Electrical Data

Supply circuit..... U = 20 ... 30 V DC
(terminals 22, 23, 24 or Um = 40 AC/DC
power rail contacts PR1 [+], PR2[-])

Control circuit..... type of protection Intrinsic Safety Ex ia IIA/IIB/IIC/IIIC
(Klemmen 4, 6) resp. Ex ib IIA/11B/IIC/IIIC

maximum values:

U_o = 9.56 V

I_o = 16.8 mA

P_o = 41 mW

linear characteristic

R_i = 567.6 Ω

L_i negligibly low

C_i negligibly low

Maximum values for individually occurring external reactances:
(according to EN 60079-11, Annex A)

	Ex ia resp. ib		
	IIA	IIB/IIIC	IIC
Lo	1 H	500 mH	125 mH
Co	210 μF	26 μF	3,6 μF

Maximum values for external reactances occurring together:
(according to Ispark 6.2)

	Ex ia resp. ib			
	IIA	IIB/IIIC	IIC	IIC
Lo	10 mH	6 mH	4 mH	3 mH
Co	5,4 μF	4,2 μF	860 nF	910 nF

active voltage output..... U ≤ 31 VDC
(terminals 7/8) I ≤ 15 mA
Um = 60 VAC/DC

relay output..... U ≤ 48 VAC/DC
(terminals 9/10) I ≤ 250 mA
Um = 60 VAC/DC

error output..... U ≤ 48 VAC/DC
(terminals 11/12) I ≤ 250 mA
Um = 60 VAC/DC

The intrinsically safe control circuit is safely electrically isolated from all other circuits up to a peak value of the nominal voltage of 375 V.



CML 23UKEX2154
Issue 0

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	22 Mar 2023	R14112CQ/00	Prime Certificate issued.

Note: Drawings that describe the equipment are listed or referred to in the Annex.

13 Conditions of Manufacture

None.

14 Specific Conditions of Use

None.

Certificate Annex

Certificate Number CML 23UKEX2154
Equipment Safety isolation amplifier type KFD2-SH-Ex1.T***
Manufacturer Pepperl+Fuchs SE



The following documents describe the equipment defined in this certificate:

Issue 0

For drawings describing the equipment, refer to attached certificate PTB 00 ATEX 2041. In addition to the drawings listed on PTB 00 ATEX 2041, the following drawings include the additional marking required for this UK Type Examination certification:

Drawing No	Sheets	Rev	Approved date	Title
16-1555CM-10	1 to 2	0	22 Mar 2023	Additional Marking Requirements for UKCA