

CERTIFICATE OF CONFORMITY

1. HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

2. Certificate No:

FM19CA0106X

3. Equipment:

(Type Reference and Name)

HD2-GTR-4PA.PN* Profinet-PA Gateway MB-FB-GTR1* Motherboard MBHC-FB-4.GT* Motherboard

4. Name of Listing Company:

PepperI+Fuchs SE

5. Address of Listing Company:

Lilienthalstrasse 200, D-68307 Mannheim, Germany

6. The examination and test results are recorded in confidential report number:

PR454421 dated 28th December 2023

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA C22.2 No. 213:2017, CSA C22.2 No. 60079-0:2015, CSA C22.2 No. 60079-7:2016, CSA C22.2 No. 60079-11:2014, CSA C22.2 No. 61010-1:2012

- 8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- 9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- 10. Equipment Ratings:

See Annex

11. The marking of the equipment shall include:

See Annex

12. Description of Equipment:

General – The PROFINET Power Hub includes the PROFINET-PA Gateway HD2-GTR-4PA.PN* and two Motherboards MB-FB-GTR1* and MBHC-FB-4.GT*. The PROFINET-PA Gateway can be plugged on a non-

Certificate issued by:

9.8. Marquerdint

J.E. Marquedant

21 March 2024

VP, Manager - Electrical Systems

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com



SCHEDULE

Canadian Certificate Of Conformity No: FM19CA0106X



redundant motherboard MBHC-FB-4.GT* or two PROFINET-PA Gateway are plugged onto a redundant motherboard MB-FB-GTR1*. The motherboard MB-FB-GTR1* can be connected via a Sub-D connection with a Fieldbus Power Hub motherboard *.HSC* or *.GEN*.

Construction - The housing corresponds to a type of protection of IP20 according to IEC 60529.

Ratings – The Fieldbus IO operates at 19.2-35 VDC. The equipment rated for use in an ambient temperature range of -40°C to +60°C or -40°C to +70°C depending on mounting.

13. Specific Conditions of Use:

- When installed in a Class I Division 2 or Zone 2 installation, the equipment shall be mounted within a tool-secured enclosure which is capable of the wiring methods specified in the Canadian Electrical Code (CSA C22.1). The equipment shall be installed in an enclosure with a minimum ingress protection rating of IP54.
- 2. Installations shall be protected to achieve a pollution degree of 2 or lower.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
28 December 2023	Original Issue.
21 March 2024	Supplement 1: Report Reference: RR239987 dated 21 March 2024. Description of the Change(s): Correct the Marking. Correct company address.

FM Approvals

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

OCPS Accrédité CON

SCHEDULE

Canadian Certificate Of Conformity No: FM19CA0106X



ANNEX

HD2-GTR-4PA.PN* Profinet-PA Gateway

Equipment Ratings:

Nonincendive for Class I Division 2, Groups A, B, C, and D; Increased Safety for Ex ec IIC T4 Gc; hazardous (classified) locations with an ambient temperature rating of up to -40°C to +70°C

Markings:

Class I Division 2, Group A, B, C, D; T4

Ex ec IIC T4 Gc

Ta = -40°C to 60°C Horizontal Mounting or -40°C to 70°C Vertical Mounting

MB-FB-GTR1* Motherboard

Equipment Ratings:

Nonincendive for Class I Division 2, Groups A, B, C, and D; Increased Safety for Ex ec IIC T4 Gc; hazardous (classified) locations with an ambient temperature rating of -40°C to +70°C

Markings:

Class I Division 2, Groups A, B, C, D; T4 Ex ec IIC T4 Gc Ta = -40°C to 70°C

MBHC-FB-4.GT* Motherboard

Equipment Ratings:

Nonincendive for Class I Division 2, Groups A, B, C, and D; Increased Safety for Ex ec IIC T4 Gc; hazardous (classified) locations with an ambient temperature rating of -40°C to +70°C

Markings:

Class I Division 2, Groups A, B, C, D; T4 Ex ec IIC T4 Gc Ta = -40°C to 70°C

To verify the availability of the Approved product, please refer to www.approvalguide.com



FM Approvals LLC. One Technology Way, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com
F 348 (Apr 21)

