MANUFACTURER'S DECLARATION OF CONFORMITY

We:

Pepperl+Fuchs SE
Lilienthalstraße 200
68307 Mannheim
Germany

declare under our own responsibility that the product(s):

ICA-SL-*-IO* IO-Link Device

See details in Annex – Conform products

to which this declaration refers conform to:

☒ IO-Link Interface and System Specification, V1.1.3, June 2019 (NOTE 1,2)

☒ IO Device Description, V1.1.3, January 2021

☒ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)

☒ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

PRDE-D1V9A

Issued at Mannheim, 2025-09-12

Authorized signatory

Name:	i.V. Dr. Konrad Kern	i.V. Lukas Pogoda
Title:	*Head of Innovation Unit Industrial Communication*	*Global Product Manager*

Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is V1.1.3, January 2021
NOTE 2 Additional validity in Package 2020 and Corrigendum

MD-Version: V1.1.3 / 2022-02

Part A - Additional conformance to Device Profiles

	Specification
☒	IO-Link Common Profile Specification, V1.1, Dec. 2021
☒	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
☐	IO-Link Smart Sensors 2nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	**Reason**
Power-on wake-up readiness delay according to Exception 24-01	This Device may delay the communication up to 3 seconds after power-on. This may result in failure reactions of the system following power-on.

Annex – Conform products

Product name	**Device ID**
ICA-SL-9MCS-70MM-IO-V1	983825 (0x0F0311)
ICA-SL-6MCS-70MM-IO-V1	983826 (0x0F0312)